



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

March 15, 1985

MEMORANDUM FOR: Hugh D. Thompson, Jr., Director
Division of Licensing

FROM: Themis P. Speis, Director
Division of Safety Technology

SUBJECT: OL REVIEW MANAGEMENT REPORT

We have reviewed the report enclosed with your memorandum of March 7, 1985, and suggest updates and corrections for Shoreham and Limerick. On Shoreham, we are still evaluating the concern regarding the ability of isolation valves in the HPCI, RCIC and RWCU lines to close under blowdown conditions. We have reviewed the PRA aspects of this problem and are awaiting information from the applicant to complete our review. To resolve this problem, the applicant must provide justification that the valves will be operable under blowdown conditions. We believe the evaluation of this concern should be added to the report. The report for Limerick notes that the ACRS recommended Limerick receive special attention in the NRC staff's consideration of USI A-17, Systems Interaction. This recommendation has been addressed in a memorandum from W. J. Dircks to R. F. Fraley dated February 12, 1985 (enclosed). We believe this staff response to the ACRS recommendation should be added to the report.

A handwritten signature in dark ink, appearing to read "Themis P. Speis", written over a horizontal line.

Themis P. Speis, Director
Division of Safety Technology

Enclosure:
2/12/85 Memo to Fraley, ACRS
from Dircks, EDO

cc: T. Novak
R. Caruso
R. Martin

8503250121

lp.

x4

6