

official

JUN 07 1985

Virginia Electric and Power Company
ATTN: Mr. W. L. Stewart, Vice President
Nuclear Operations
P. O. Box 26666
Richmond, VA 23261

Gentlemen:

SUBJECT: SURRY POWER STATION EMERGENCY PLAN REVIEW
DOCKET NOS. 50-280 AND 50-281

We have completed our review of your February 14, 1985, and April 16, 1985, revisions to the Surry Power Station Emergency Plan. Our review indicates the revisions meet the planning standard of 10 CFR 50.47(b).

Please be reminded that 10 CFR 50.54(q) requires NRC approval of any changes to your Plan that may decrease the effectiveness of the Plan. However, if your safety review indicates no decrease in emergency preparedness, then changes can be made without NRC approval. In all cases, you should furnish copies of each change to the NRC in accordance with 10 CFR 50.54(q). Also, any changes to the Emergency Plan Implementing Procedures should be made in accordance with the requirements of 10 CFR, Appendix E, Section V (Implementing Procedures).

Should you have any questions regarding this letter, please contact Mr. W. E. Cline, of my staff at 404/221-2665.

Sincerely,

Virgil L. Brownlee, Chief
Reactor Projects Branch 2
Division of Reactor Projects

cc: R. F. Saunders, Station Manager
R. J. Hardwick, Jr., Manager -
Nuclear Programs and Licensing

bcc: NRC Resident Inspector
Document Control Desk
Commonwealth of Virginia
EP Section Files

RII
WS
WSartor
5/31/85

RII
WC
WCline
5/5/85

RII
DC
DCollins
5/5/85

RII
SE
SElrod
5/5/85

8507120010 850607
PDR ADOCK 05000280
F PDR

110
IE35