

Yellow

June 10, 1985

South Carolina Electric and Gas Company
ATTN: Mr. O. W. Dixon, Jr.
Vice President, Nuclear Operations
P. O. Box 764 (167)
Columbia, SC 29218

Gentlemen:

SUBJECT: REPORT NO. 50-395/85-11

Thank you for your response of May 10, 1985, to our Notice of Violation issued on April 11, 1985, concerning activities conducted at your Summer facility. Your response was amended in a telephone conversation on May 29, 1985, with Messrs. A. Koon and J. Connelly to include the provision that the safety-related portion of measuring and test equipment out-of-tolerance evaluations will be completed within seven days. This will include the identification of equipment usage since the last calibration and the analysis of the effect on plant safety. The balance of the report will then be completed within 90 days.

We have evaluated your amended response and found that it meets the requirements of 10 CFR 2.201. We will examine the implementation of your corrective actions during future inspections.

We appreciate your cooperation in this matter.

Sincerely,

Original Signed by
Roger D. Walker

Roger D. Walker, Director
Division of Reactor Projects

cc: O. S. Bradham, Director, Nuclear
Plant Operations
B. G. Croley, Group Manager
Technical & Support Services
D. A. Lavigne,
Associate Manager, QA
J. B. Knotts, Jr.

bcc: NRC Resident Inspectors
J. Hopkins, Project Manager, NRR
Document Control Desk
State of South Carolina

RII
MR
MRunyan
06/5/85

RII
CU
CUpright
06/5/85

RII
AG
AGibson
06/5/85

RII
PB
PBemis
06/6/85

RII
FC
FCantrell
06/10/85

RII
DV
DVerrelli
06/10/85

8507120048 850610
PDR ADOCK 05000395
Q PDR

IE01