GULF STATES UTILITIES COMPANY

RIVER BEND STATION · POST OFFICE BOX 220 · ST. FRANCISVILLE, LOUISIANA 70775

AREA CODE 504 · 635-6094 · 346-8651

June 25, 1985
RBG- 21,385
File Nos. G9.5, G9.25.1.1

Mr. Robert D. Martin, Regional Administrator
U. S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011

Dear Mr. Martin:

River Bend Station - Unit 1
Docket No. 50-458
Final Report/DR-273

Gulf States Utilities Company (GSU) has completed its evaluation of DR-273 concerning the relocation of Rosemount transmitters to new environmental zones. Given the environmental conditions for the new zones, it was determined that the transmitters will perform their intended safety function. GSU has therefore determined that this condition is not reportable under 10CFR50.55(e).

Sincerely,

J. E. Booker

J. E. Booker
Manager-Engineering,
Nuclear Fuels & Licensing
River Bend Nuclear Group

JEB/PJD/amg

cc: Director of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

NRC Resident Inspector-Site

8507120222 850625
PDR ADOCK 05000458
S PDR

RECEIVED
JUN 28 1985

85-534

IE-27