



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

40
DEC 27 1977

MEMORANDUM FOR: T. M. Su, Task Manager (A-39), Containment Systems Branch, DSS

FROM: L. C. Shao, Chief, Engineering Branch, DOR

SUBJECT: COMMENTS ON REVISION 1 TO TASK A-39

The Engineering Branch, Division of Operating Reactors, has reviewed your proposed Revision 1 to Category A Task A-39, "Determination of Safety/Relief Value (SRV) Pool Dynamic Loads and Temperature Limits for BWR Containments." As a result of our review, we recommend that on page 18, under the statement of Engineering Branch, DOR involvement in Tasks 1b and 2c, the statements that a "pure forcing function" to account for FSI effects will be obtained be changed such that it is stated that an "appropriate forcing function" will be determined. At this time, we are not sure that a "pure" forcing function, void of FSI effects, can be obtained. Therefore, a representative forcing function may have to be determined instead.

-PS-CSB-DSS -

28 DEC 77 10:22


L. C. Shao, Chief
Engineering Branch
Division of Operating Reactors

Contact: K. Herring
28060

cc: D. Eisenhut
R. Cudlin
J. Guilbert
J. Knight
R. Mattson
V. Noonan
R. Stuart
S. Hosford
R. LaGrange
K. Wichman
J. Zudans
K. Herring

B604020428 B60114
PDR FOIA
FIREST085-665 PDR

D-86