

## EMERGENCY CORE COOLING SYSTEMS

### SURVEILLANCE REQUIREMENTS (Continued)

---

- i. Each time HPSI Pump A/B is placed in or taken out of service in place of HPSI Pump A or B, the pump being placed in service shall be demonstrated OPERABLE by:
  1. Verifying that each valve in the flow path is in its correct position; and
  2. Verifying the pump starts manually and upon receipt of a SIAS test signal; and
  3. Performing Surveillance Requirement 4.5.2f.1., if not previously accomplished within the required frequency.
- j. Following any maintenance which drains portions of the system, by ~~venting the ECCS pump casings and discharge piping high points~~ verifying the ECCS piping is full of water.

9705120327 970506  
PDR ADOCK 05000382  
P PDR