

Callaway Plant
Post Office Box 620
Fulton, Missouri 65251
573-676-8245
573-676-4056 Fax



May 29, 1997

Garry L. Randolph
Vice President and
Chief Nuclear Officer

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Mail Stop P1-137
Washington, DC 20555-0001

ULNRC-3584

Gentlemen:


DOCKET NUMBER 50-483
CALLAWAY PLANT
RADIOLOGICAL EMERGENCY RESPONSE PLAN, REV. 21

Enclosed is one (1) copy of Revision 21 of the Callaway Plant Radiological Emergency Response Plan (RERP). This document will be implemented July 1, 1997, in accordance with Callaway Plant procedures and 10CFR50.54(q).

In addition to minor editing, this revision includes the following changes: modification of the Emergency Response Organization to place the focus of the TSC on the on-site activities and the focus of the EOF on the off-site responsibilities, key coordinators are designated as 60 minute (rapid responders) to relieve the control room of plant assessment, classifications, protective actions, dose assessment, off-site communications, and EOF responsibilities, dose assessment and off-site notifications will be transferred directly from the Control Room to the EOF, all field monitoring activities will be done from the EOF, installed habitability monitors will be replaced with portable instrumentation in the emergency response facilities; and the Letters of Agreement were reviewed and updated as needed.


Revision 21 of the RERP does not decrease the effectiveness of emergency preparedness at the Callaway Plant. The plan will continue to meet the standards of 10CFR50.47(b) and the requirements of 10CFR50.54(q).

Sincerely,


Garry L. Randolph

9706180079 970529
PDR ADOCK 05000483
F PDR

GLR/JLN/SJC/rjp
Enclosure



May 26, 1997

Page 2

cc: Mr. Ellis W. Merschoff (2 copies)
Regional Administrator
U.S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011-8064

Senior Resident Inspector
Callaway Resident Office
U.S. Nuclear Regulatory Commission
8201 NRC Road
Steedman, MO 65077

Ms. Kristine M. Thomas (2 copies)
Licensing Project Manager, Callaway Plant
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Mail Stop 13E16
Washington, DC 20555-2738

Manager, Electric Department
Missouri Public Service Commission
PO Box 360
Jefferson City, MO 65102

Mr. Thomas A. Baxter
Shaw, Pittman, Potts, & Trowbridge
2300 N. Street N.W.
Washington, DC 20037

Senior Emergency Preparedness Analyst
U. S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011-8064