

In Reply Refer To:
Docket: 50-445/85-19

MAR 28 1986

Texas Utilities Generating Company
ATTN: Mr. W. G. Council
Executive Vice President
400 North Olive, L.B. 81
Dallas, Texas 75201

Gentlemen:

This refers to the special inspection conducted by Mr. T. F. Westerman, members of the Region IV Comanche Peak Group, and NRR personnel during the period of November 18 through December 18, 1985, of activities authorized by NRC Construction Permit CPPR-126 for the Comanche Peak Steam Electric Station, Unit 1, and to discussions with Mr. R. E. Camp and other members of your staff on November 22, 1985, and December 5, 1985.

The purpose of the special inspection was to evaluate the Comanche Peak Steam Electric Station, Unit 1 as-built cable tray inspection program. The inspection identified multiple instances involving the failure to properly inspect and document as-built cable tray attributes. In addition, violations were identified relative to both the failure of the QA programs to establish QA overview and audits of the Unit 1 as-built cable tray inspection program and the use of incorrect weld bevel angles. The violations and related NRC concerns were discussed with you in the subsequent exit meeting held on December 18, 1985.

No response to this letter is requested. Enforcement actions relative to this inspection will be forwarded under separate correspondence.

RIV:CPG
IBarnes;ap
3/28/86
IB

C:CPG *B*
TWesterman
3/28/86

AD:DRS&P *SW*
EJohnson
3/28/86

ES *dLP*
DPowers
3/28/86

NRR *for 2 per telephone call to C. Hargrave*
VNoonan
3/28/86

B604040109 B60328
PDR ADOCK 05000445
G PDR

IEO1
1/1

Should you have any questions concerning this letter, we will be glad to discuss them with you.

Sincerely,

Original Signed By
E. H. Johnson

E. H. Johnson, Director
Division of Reactor Safety
and Projects

Enclosure:
Appendix - NRC Inspection Report
50-445/85-19

cc w/encl:
Texas Utilities Electric Company
ATTN: J. W. Beck, Vice President Licensing
Quality Assurance and Nuclear Fuels
Skyway Tower
400 North Olive Street
Lock Box 81
Dallas, Texas 75201

Juanita Ellis
President - CASE
1426 South Polk Street
Dallas, Texas 75114

Renea Hicks
Assistant Attorney General
Environmental Protection Division
P. O. Box 12549
Austin, Texas 76711

Texas Radiation Control Program Director

bcc to DMB (IE01)

bcc distrib. by RIV:

| | |
|---------------------------|----------------|
| *RPB | *MIS System |
| *RRI-OPS | *RSTS Operator |
| *RRI-CONST | *R&SPB |
| *TFWesterman, CPTG | DRSP |
| V. Noonan, NRR | R. Martin, RA |
| S. Treby, ELD | *RSB |
| *RIV File | J. Taylor, IE |
| *D. Weiss, LFMB (AR-2015) | |
| R. Heishman, IE | *D. Powers, EC |

*w/766