

Docket No. 50-231

X

X

1-22-71

151
Peter A. Morris, Director, Division of
Reactor Licensing, USAEC, Washington, D. C.
20545

General Electric Company
ATTN: Dr. Karl Cohen, General Manager
Breeder Reactor Development Operation
310 DeGuigne Drive
Sunnyvale, California

WE HAVE REACHED THE STAGE IN
OUR REVIEW OF YOUR APPLICATIONS REQUESTING AUTHORIZATION TO PROCEED TO THE 20 MWt
TESTING PHASE FOR THE SEFOR WHERE WE CAN CONCLUDE THAT STEADY STATE OPERATION AT
POWER LEVELS UP TO 20 MWt CAN BE CONDUCTED AND OPERATION IN THE MANNER PROPOSED
WILL PROVIDE REASONABLE ASSURANCE THAT THE HEALTH AND SAFETY OF THE PUBLIC WILL
NOT BE ENDANGERED.

WE ARE CONTINUING OUR REVIEW IN ORDER TO ASCERTAIN THE LIMITATIONS REQUIRED FOR
TRANSIENT OPERATION.

THE TECHNICAL SPECIFICATIONS APPENDED TO LICENSE NO. DR-15 ARE HERE AMENDED AS
FOLLOWS:

SPECIFICATION 3.10.E

DELETE THE WORDS "INITIAL OPERATION AT 20 MWt AND . . ."

SPECIFICATION 3.3.H

DELETE THE SECOND SENTENCE

SPECIFICATION 3.13

ADD THE SECTION PROPOSED IN REVISION 2 TO PROPOSED CHANGE NO. 4

OFFICE ▶ RBSchemel, DRL	DRL 151	DRL 151	DRL 151						
SURNAME ▶ X7483 RJSchemel:bsp	DJSkovh. Bv	PAMorris							
DATE ▶ 1/21	1/21	1-22-71							

Form AEC-318 (Rev. 9-53) AECM 0240

U. S. GOVERNMENT PRINTING OFFICE : 1968 O-296-617

9705130209 970505
PDR FOIA
VARADY97-34 PDR

U.S. ATOMIC ENERGY COMMISSION
OUTGOING TELECOMMUNICATION MESSAGETHIS DOCUMENT
NO.CONSISTS OF _____ PAGES
OF _____ COPIES, SERIES

(See reverse side for instructions)

PRECEDENCE DESIGNATION (Check appropriate boxes. Average transmission time exclusive of messenger services is shown.)

ACTION: ☐ DEFERRED (2-4 Hrs.) ☐ ROUTINE (1-1 1/2 Hrs.) ☒ PRIORITY (1/2-1 Hr.)
INFO: ☐TYPE OF MESSAGE
(Check one)☒ SINGLE ADDRESS
☐ MULTIPLE ADDRESS
☐ BOOK MESSAGE

FOR COMMUNICATION CENTER USE

MESSAGE IDENTIFICATION

NR:

DTG:

2

FROM: Peter A. Morris, Director, Division of
Reactor Licensing, USAEC, Washington, D. C.
20545

OFFICIAL BUSINESS

(Signature of certifying official)

DATE OF MESSAGE:

TO: Docket No. 50-231
General Electric Company
ATTN: Dr. Karl Coher, General Manager
Breeder Reactor Development Operation
310 DeGuigne Drive
Sunnyvale, California

COMMUNICATION CENTER ROUTING

WE HAVE REACHED THE STAGE IN
OUR REVIEW OF YOUR APPLICATIONS REQUESTING AUTHORIZATION TO PROCEED TO THE 20 MWt
TESTING PHASE FOR THE SEFOR WHERE WE CAN CONCLUDE THAT STEADY STATE OPERATION AT
POWER LEVELS UP TO 20 MWt CAN BE CONDUCTED AND OPERATION IN THE MANNER PROPOSED
WILL PROVIDE REASONABLE ASSURANCE THAT THE HEALTH AND SAFETY OF THE PUBLIC WILL
NOT BE ENDANGERED.

WE ARE CONTINUING OUR REVIEW IN ORDER TO ASCERTAIN THE LIMITATIONS REQUIRED FOR
TRANSIENT OPERATION.

THE TECHNICAL SPECIFICATIONS APPENDED TO LICENSE NO. DR-15 ARE HERE AMENDED AS
FOLLOWS:

SPECIFICATION 3.10.E

DELETE THE WORDS "INITIAL OPERATION AT 20 MWt AND . . ."

SPECIFICATION 3.3.H

DELETE THE SECOND SENTENCE

SPECIFICATION 3.13

ADD THE SECTION PROPOSED IN REVISION 2 TO PROPOSED CHANGE NO. 4

BE BRIEF--ELIMINATE UNNECESSARY WORDS

ORIGINATOR:

REchemel, DRL
X7433

INSERT CLASSIFICATION (If Classified)

RESTRICTED DATA OR ESPIONAGE STAMP, IF REQUIRED