

May 9, 1997

Mr. Nicholas J. Liparulo, Manager  
Nuclear Safety and Regulatory Activities  
Nuclear and Advanced Technology Division  
Westinghouse Electric Corporation  
P.O. Box 355  
Pittsburgh, Pennsylvania 15230

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION (RAI) ON THE AP600 ADVANCED  
REACTOR DESIGN REGARDING THE SOLID RADIOACTIVE WASTE SYSTEM

Dear Mr. Liparulo:

The Nuclear Regulatory Commission staff has determined that it needs additional information in order to continue its review of the Westinghouse AP600 advanced reactor design. The enclosure is RAI# 460.27 regarding standard safety analysis report Section 11. Because of the design changes in AP600 solid waste system, the Plant Systems Branch needs additional information to re-review the issue of onsite waste storage capacity. This issue was found acceptable in the draft safety evaluation report (DSER). However, the basis for the acceptance in the DSER is not valid in the revised design.

If you have any questions regarding this matter, you may contact me at (301) 415-8548.

Sincerely,

original signed by:

Diane T. Jackson, Project Manager  
Standardization Project Directorate  
Division of Reactor Program Management  
Office of Nuclear Reactor Regulation

Docket No. 52-003

Enclosure: As stated

cc w/enclosure:  
See next page

DISTRIBUTION:

Docket File  
PUBLIC  
TKenyon  
DJackson  
CLi, 0-8 D1

PDST R/F  
TRQuay  
BHuffman  
JMoore, 0-15 B18  
LMarsh, 0-8 D1

MSlosson  
JSebrosky  
WDean, 0-17 G21  
ACRS (11)  
GHolahan, 0-8 E2

130053

DOCUMENT NAME: A:CH115 97.RAI

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	PM:PDST:DRPM	BC:SPLB:DSSA	D:PDST:DRPM				
NAME	DTJackson <i>DT</i>	LMarsh <i>LM</i>	TRQuay <i>TRQ</i>				
DATE	05/7/97	05/08/97	05/9/97				

9705130358 970509  
PDR ADDCK 05200003  
E PDR

OFFICIAL RECORD COPY

NRC FILE CENTER COPY

Mr. Nicholas J. Liparulo  
Westinghouse Electric Corporation

Docket No. 52-003  
AP600

cc: Mr. B. A. McIntyre  
Advanced Plant Safety & Licensing  
Westinghouse Electric Corporation  
Energy Systems Business Unit  
P.O. Box 355  
Pittsburgh, PA 15230

Mr. Ronald Simard, Director  
Advanced Reactor Programs  
Nuclear Energy Institute  
1776 Eye Street, N.W.  
Suite 300  
Washington, DC 20006-3706

Ms. Cindy L. Haag  
Advanced Plant Safety & Licensing  
Westinghouse Electric Corporation  
Energy Systems Business Unit  
Box 355  
Pittsburgh, PA 15230

Ms. Lynn Connor  
Doc-Search Associates  
Post Office Box 34  
Cabin John, MD 20818

Mr. M. D. Beaumont  
Nuclear and Advanced Technology Division  
Westinghouse Electric Corporation  
One Montrose Metro  
11921 Rockville Pike  
Suite 350  
Rockville, MD 20852

Mr. James E. Quinn, Projects Manager  
LMR and SBWR Programs  
GE Nuclear Energy  
175 Curtner Avenue, M/C 165  
San Jose, CA 95125

Mr. Sterling Franks  
U.S. Department of Energy  
NE-50  
19901 Germantown Road  
Germantown, MD 20874

Mr. Robert H. Buchholz  
GE Nuclear Energy  
175 Curtner Avenue, MC-781  
San Jose, CA 95125

Barton Z. Cowan, Esq.  
Eckert Seamans Cherin & Mellott  
600 Grant Street 42nd Floor  
Pittsburgh, PA 15219

Mr. S. M. Modro  
Nuclear Systems Analysis Technologies  
Lockheed Idaho Technologies Company  
Post Office Box 1625  
Idaho Falls, ID 83415

Mr. Ed Rodwell, Manager  
PWR Design Certification  
Electric Power Research Institute  
3412 Hillview Avenue  
Palo Alto, CA 94303

Mr. Frank A. Ross  
U.S. Department of Energy, NE-42  
Office of LWR Safety and Technology  
19901 Germantown Road  
Germantown, MD 20874

Mr. Charles Thompson, Nuclear Engineer  
AP600 Certification  
NE-50  
19901 Germantown Road  
Germantown, MD 20874

REQUESTS FOR ADDITIONAL INFORMATION  
PLANT SYSTEM BRANCH  
WESTINGHOUSE AP600 SSAR SECTION 11

In Section 11.4 of the DSER, the staff reviewed the AP600 solid waste system regarding the amount of shipment and onsite storage capacity and found it acceptable. However, Westinghouse changed the design after the DSER was issued, and the onsite storage spaces identified in the DSER do not exist any more. The bases for the DSER finding is no longer valid. In order to re-review the storage capacity for solid waste, the staff requests the following information:

460.27 In a telecon of April 8, 1997, Westinghouse stated that: in the revised design, two spent resin tanks and nine spent filter tubes in the auxiliary building, and a packaged waste storage room in the radwaste building are designed for onsite storage. The remaining solid waste is expected to be shipped offsite. If this is correct, the staff finds the information in Section 11.4 of the SSAR to be incomplete. For example, the number of spent filter tubes and their storage capacity, and the expectation for the COL applicant to provide sufficient shipment capability by a mobile systems are not specified in the SSAR.

- a. Revise the SSAR to address the above staff concern.
- b. Using the data in SSAR Table 11.4-1, Westinghouse is requested to demonstrate that the AP600 has sufficient storage capacity to allow time for short-lived radionuclides to decay prior to shipping in accordance with the regulatory guidance in the standard review plan (SRP) Section 11.4, Paragraphs II.6 and III.4, and BTP ETSB 11-3 Position B.III.
- c.
  1. In SSAR Table 11.4-1, the amount of "expected" generation and "expected" shipped solid waste are significantly lower than that of "maximum" generation and "maximum" shipped solid waste. Clarify whether the designed process and storage capacity are based on the "expected" amount or on the "maximum" amount.

If the design storage capacity is based on the expected amount:

2. explain how the AP600 will handle the waste that is beyond what is expected, and
3. compare the values given in the SSAR for the volumes and radionuclide content of solid waste to be shipped offsite with data from operating plants of similar size.

Enclosure