

Commonwealth Edison Company
Quad Cities Generating Station
22710 290th Avenue North
Cordova, IL 61242-9700
Tel 309-654-2241

LWP-97-051

ComEd

May 2, 1997

United States Nuclear Regulatory Commission
Washington, DC 20555

Attention: Document Control Desk

Reference: Quad Cities Nuclear Power Station
Docket Number 50-254, DPR-29, Unit One
Docket Number 50-265, DPR-30, Unit Two

Enclosed is Licensee Event Report (LER) 97-010, Revision 00, for Quad Cities Nuclear Power Station.

This report is submitted in accordance with the requirements of the Code of Federal Regulations, Title 10, Part 50.73(a)(2)(v)(D). The licensee shall report any event or condition that alone could have prevented the fulfillment of the safety function of structures or systems that are needed to mitigate the consequences of an accident.

The following commitment is being made by this letter:

Engineering Request #9702678 was originated by System Engineering to perform a complete vibration assessment of the compressor/condenser skid as well as all refrigerant piping. Activities required as a result of this assessment will be tracked on subsequent NTS numbers.

If there are any questions or comments concerning this letter, please refer them to Charles Peterson, Regulatory Affairs Manager at 309-654-2241, ext. 3609.

Respectfully,

COMMONWEALTH EDISON COMPANY
QUAD CITIES NUCLEAR POWER STATION

L. W. Pearce
L. W. Pearce
Station Manager

LWP/CP/plm
Enclosure

cc: A. B. Beach, Regional Administrator, Region III
R. M. Pulsifer, Project Manager, NRR
C. G. Miller, Senior Resident Inspector, Quad Cities
W. D. Leech, MidAmerican Energy Company
D. C. Tubbs, MidAmerican Energy Company
P. L. Piet, Licensing, ComEd
F. A. Spangenberg, Regulatory Affairs Manager, Dresden
INPO Records Center

130054

9705130378 970502
PDR ADOCK 05000254
S PDR

