



SAFEGUARDS INFORMATION

UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION II
101 MARIETTA STREET, N.W.
ATLANTA, GEORGIA 30323

Report Nos. 50-269/85-28, 50-270/85-28, and 50-287/85-28

Licensee: Duke Power Company
422 Church Street
Charlotte, NC 28242

Docket Nos. 50-269, 270, and 287

License Nos. DPR-38, 47, and 55

Facility Name: Oconee Nuclear Station

Inspection Date: September 3-6, 1985

Inspector: *C. D. Perny*
C. D. Perny, Physical Security Inspector

10/2/85
Date Signed

O. M. Masnyk
O. M. Masnyk, Physical Security Specialist

10-02-85
Date Signed

Approved by: *D. R. McGuire*
D. R. McGuire, Chief, Physical Security Section
Nuclear Materials Safety and Safeguards Branch
Division of Radiation Safety and Safeguards

10/2/85
Date Signed

SUMMARY

Scope: This routine, unannounced inspection involved 64 inspector-hours on site (6 hours backshift) by two inspectors inspecting Security Plan and Implementing Procedures; Security Organization; Security Program Audits, Records and Reports; Physical Barriers- Protected Area; Physical Barriers - Vital Area; Security System Power Supply; Lighting; Assessment Aids; Detection Aids - Protected and Vital Areas; Alarm Stations and Communications.

Results: Three violations were identified: inadequate procedure for documentation of vital area barrier inspection (85-28-01); failure to meet the alarm annunciation requirement in the Physical Security Plan (85-28-02); and breach of a vital area barrier (85-28-03). One unresolved item was identified in the area of physical barriers - protected area (85-28-04).

8510240392 851017
PDR ADDCK 05000269
Q PDR

ENCLOSURE CONTAINS
SAFEGUARDS INFORMATION
UPON SEPARATION THIS
PAGE IS DECONTROLLED.

SAFEGUARDS INFORMATION