

Commonwealth Edison Company
Quad Cities Generating Station
22710 200th Avenue North
Cordova, IL 61229-740
Tel 809-654-2241

ComEd

LWP-97-47

May 1, 1997

United States Nuclear Regulatory Commission
Washington, DC 20555

Attention: Document Control Desk

Reference: Quad Cities Nuclear Power Station
Docket Number 50-254, DPR-29, Unit One
Docket Number 50-265, DPR-30, Unit Two

Enclosed is Licensee Event Report (LER) 97-011, Revision 00, for Quad Cities Nuclear Power Station.

This report is submitted in accordance with the requirements of the Code of Federal Regulations, Title 10, Part 50.73(a)(2)(i)(A). The licensee shall report the completion of any nuclear plant shutdown required by the plant's Technical Specifications.

This report is also submitted in accordance with the requirements of the Code of Federal Regulations, Title 10, Part 50.73 (a)(2)(v)(B). The licensee shall report any event or condition that alone could have prevented the fulfillment of the safety function of structures or systems that are needed to remove residual heat.

The following commitments are being made by this letter:

1. Complete DCP 97000144 to install a mounting strap for Unit 2 breakers prior to start up from Q2R14.
2. Evaluate the feasibility of extending the qualification of the mounting strap design by the end of Q1R15 and Q2R15.

9705140168 970501
PDR ADDCK 05000254
S PDR

STMGR\04797.LWP




May 1, 1997

If there are any questions or comments concerning this letter, please refer them to Charles Peterson, Regulatory Affairs Manager at 309-654-2241, ext. 3609.

Respectfully,

COMMONWEALTH EDISON COMPANY
QUAD CITIES NUCLEAR POWER STATION


L. W. Pearce
Station Manager

LWP/CP/plm
Enclosure

cc: A. B. Beach, Regional Administrator, Region III
R. M. Pulsifer, Project Manager, NRR
C. G. Miller, Senior Resident Inspector, Quad Cities
W. D. Leech, MidAmerican Energy Company
D. C. Tubbs, MidAmerican Energy Company
P. L. Piet, Licensing, ComEd
F. A. Spangenberg, Regulatory Affairs Manager, Dresden
INPO Records Center