

Commonwealth Edison Company  
Quad Cities Generating Station  
22710 206th Avenue North  
Gordova, IL 61242-9740  
Tel 309-654-2241



LWP-97-054

May 8, 1997

United States Nuclear Regulatory Commission  
Washington, DC 20555

Attention: Document Control Desk

Reference: Quad Cities Nuclear Power Station  
Docket Number 50-254, DPR-29, Unit One

Enclosed is Licensee Event Report (LER) 97-013, Revision 00, for Quad Cities Nuclear Power Station.

This report is submitted in accordance with the requirements of the Code of Federal Regulations, Title 10, Part 50.73(a)(2)(vii)B. The licensee shall report any single cause of inoperable independent train or channel in a single system designed to remove residual heat.

The following commitment is being made by this letter: A change will be made to QCIS 1300-05 and QCIS 2300-07, "Refuel HPCI Turbine Area High Temperature Isolation Calibration and Functional Test", to add a caution on the amount of sealing varnish applied to set screws and to include a requirement to bench test switches if and after varnish has been applied after calibration adjustments; (expected completion date 040198).

If there are any questions or comments concerning this letter, please refer them to Charles Peterson, Regulatory Affairs Manager at 309-654-2241, ext. 3609.

Respectfully,

COMMONWEALTH EDISON COMPANY  
QUAD CITIES NUCLEAR POWER STATION

*L. W. Pearce*  
L. W. Pearce  
Station Manager

LWP/CP/plm

Enclosure

cc: A. B. Beach, Regional Administrator, Region III  
R. M. Pulsifer, Project Manager, NRR  
C. G. Miller, Senior Resident Inspector, Quad Cities  
W. D. Leech, MidAmerican Energy Company  
D. C. Tubbs, MidAmerican Energy Company  
P. L. Piet, Licensing, ComEd  
F. A. Spangenberg, Regulatory Affairs Manager, Dresden  
INPO Records Center

130168

9705140179 970508  
PDR ADOCK 05000254  
S PCR

A. E. Edison Company

