

Commonwealth Edison Company  
Quad Cities Generating Station  
22710 206th Avenue North  
Cordova, IL 61242-9740  
Tel 309-654-2241

**ComEd**

LWP-97-053

May 8, 1997

United States Nuclear Regulatory Commission  
Washington, DC 20555

Attention: Document Control Desk

Reference: Quad Cities Nuclear Power Station  
Docket Number 50-254, DPR-29, Unit One

Enclosed is Licensee Event Report (LER) 97-015, Revision 00, for Quad Cities Nuclear Power Station.

This report is submitted in accordance with the requirements of the Code of Federal Regulations, Title 10, Part 50.73(a)(2)(iv). The licensee shall report any event or condition that resulted in manual or automatic actuation of any Engineered Safety Feature.

The following commitment is being made by this letter:

The breakers in EPAs 1A-1, 1A-2, 1AB-1, 1AB-2, 1B-1, 2B-1, 2A-1, and 2AB-2 will be replaced with new 2-pole breakers. The breakers in EPAs 1B-2, 2A-2, 2B-2, and 2AB-1 are newer 2-pole breakers. The breaker in 1B-2 was replaced with a 2-pole breaker at this time. To be completed 050198.

If there are any questions or comments concerning this letter, please refer them to Charles Peterson, Regulatory Affairs Manager at 309-654-2241, ext. 3609.

Respectfully,

COMMONWEALTH EDISON  
QUAD CITIES NUCLEAR POWER STATION

*L.W. Pearce*  
L. W. Pearce  
Station Manager

LWP/CP/plm

Enclosure

cc: A. B. Beach, Regional Administrator, Region III  
R. M. Pulsifer, Project Manager, NRR  
C. G. Miller, Senior Resident Inspector, Quad Cities  
W. D. Leech, MidAmerican Energy Company  
D. C. Tubbs, MidAmerican Energy Company  
P. L. Piet, Licensing, ComEd  
F. A. Spangenberg, Regulatory Affairs Manager, Dresden  
INPO Records Center

130169  
9705140188 970508  
PDR ADOCK 05000254  
S PDR



A Lincoln Company