

March 27, 1986

Docket No.: 50-213

Mr. John F. Opeka, Senior Vice President
Nuclear Engineering and Operations
Northeast Nuclear Energy Company
Post Office Box 270
Hartford, Connecticut 06141-0270

Dear Mr. Opeka:

SUBJECT: ENVIRONMENTAL ASSESSMENT AND FINDING
OF NO SIGNIFICANT IMPACT

Re: Haddam Neck Plant

Enclosed is the Environmental Assessment related to your application dated December 6, 1985, as modified January 7, 1986, for changes to the Haddam Neck Plant technical specifications to permit the repair of degraded steam generator tubes by installing metal sleeves in the degraded tubes rather than removing them from service by plugging them.

Also enclosed is a copy of the Notice of Issuance of Environmental Assessment and Finding of No Significant Impact, which has been sent to the Office of the Federal Register for publication.

Sincerely,

Original signed by : C. I. Grimes

Christopher I. Grimes, Director
Integrated Safety Assessment
Project Directorate
Division of PWR Licensing - B

Enclosure:
As Stated

cc w/enclosure:
See Next Page

DISTRIBUTION

Docket File

ISAP Reading
Local PDR
NRC PDR
F. Miraglia
OELD
E. Jordan
B. Grimes

J. Partlow
P. Anderson
ACRS (10)
NSIC
OPA

ISAP:DPL-B *[Signature]*
FAkstulewicz:lt
03/18/86

ISAP:DPL-B *[Signature]*
PAnderson
03/19/86

ISAP:DPL-B *CGI*
CGrimes
03/20/86
27

OELD *[Signature]*
03/24/86

8604040559 860327
PDR ADOCK 05000213
P PDR



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

March 27, 1986

Docket No.: 50-213

Mr. John F. Opeka, Senior Vice President
Nuclear Engineering and Operations
Northeast Nuclear Energy Company
Post Office Box 270
Hartford, Connecticut 06141-0270

Dear Mr. Opeka:

SUBJECT: ENVIRONMENTAL ASSESSMENT AND FINDING
OF NO SIGNIFICANT IMPACT

Re: Haddam Neck Plant

Enclosed is the Environmental Assessment related to your application dated December 6, 1985, as modified January 7, 1986, for changes to the Haddam Neck Plant technical specifications to permit the repair of degraded steam generator tubes by installing metal sleeves in the degraded tubes rather than removing them from service by plugging them.

Also enclosed is a copy of the Notice of Issuance of Environmental Assessment and Finding of No Significant Impact, which has been sent to the Office of the Federal Register for publication.

Sincerely,

A handwritten signature in cursive script that reads "Christopher I. Grimes".

Christopher I. Grimes, Director
Integrated Safety Assessment
Project Directorate
Division of PWR Licensing - B

Enclosures:
As Stated

cc w/enclosure:
See Next Page

Mr. John F. Opeka
Connecticut Yankee Atomic Power Company

Haddam Neck Plant

cc:

Gerald Garfield, Esquire
Day, Berry & Howard
Counselors at Law
City Place
Hartford, Connecticut 06103-3499

Superintendent
Haddam Neck Plant
RDF #1
Post Office Box 127E
East Haddam, Connecticut 06424

Edward J. Mroczka
Vice President, Nuclear Operations
Northeast Utilities Service Company
Post Office Box 270
Hartford, Connecticut 06141-0270

Board of Selectmen
Town Hall
Haddam, Connecticut 06103

State of Connecticut
Office of Policy and Management
ATTN: Under Secretary Energy
Division
80 Washington Street
Hartford, Connecticut 06106

Resident Inspector
Haddam Neck Nuclear Power Station
c/o U.S. NRC
East Haddam Post Office
East Haddam, Connecticut 06423

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, Pennsylvania 19406

Kevin McCarthy, Director
Radiation Control Unit
Department of Environmental
Protection
State Office Building
Hartford, Connecticut 06106

Richard M. Kacich, Supervisor
Operating Nuclear Plant Licensing
Northeast Utilities Service Company
Post Office Box 270
Hartford, Connecticut 06141-0270