

Fermi 2  
6400 North Dixie Hwy., Newport, Michigan 48166  
Tel: 313.586.5201 Fax: 313.586.4172

10CFR50.73

May 8, 1997  
NRC-97-0052

**Detroit Edison**



U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, D. C. 20555

Reference: 1) Fermi 2  
NRC Docket No. 50-341  
NRC License No. NPF-43  
  
2) Detroit Edison Letter to NRC, NRC-97-0021, "Licensee Event  
Report (LER) 97-003," dated April 2, 1997

Subject: Licensee Event Report (LER) No. 97-003, Revision 1

Pursuant to 10CFR50.73, Detroit Edison is submitting the enclosed LER  
No. 97-003, Revision 1 documenting a condition outside the design basis related  
to the Emergency Equipment Cooling Water System (EECWS) containment  
isolation function and the subsequent identification of several bypass leakage  
paths which were not previously recognized.

The diverse power modification of the EECWS primary containment penetrations  
identified as a commitment in the original submittal of this LER has been  
completed. There are no new commitments made in this LER.

If you have any questions, please contact Andrew V. Antrassian, Compliance  
Engineer, at (313) 586-1856.

Sincerely,

cc: A. B. Beach  
G. A. Harris  
M. J. Jordan  
A. J. Kugler  
Region III  
M. V. Yudas, Jr.

Wayne County Emergency Management Division

