

FEB 7 1973

DISTRIBUTION

✓ Docket File  
AEC PDR  
Local PDR  
RP Reading File  
Branch Reading File  
J. R. Buchanan, ORNL  
T. W. Laughlin, DTIC  
D. J. Skovholt  
T. J. Carter  
R. J. Schemel  
P. B. Erickson  
S. A. Teets  
ACRS (16)  
RO (3)  
OGC  
M. Jinks (4)  
N. Dube

Docket No. 50-231

General Electric Company  
ATTN: Dr. Bertram Wolfe  
General Manager  
Breeder Reactor Department  
310 DeGuligne Drive  
Sunnyvale, California 94086

Gentlemen:

Change No. 16  
License No. DR-15

By letter dated January 24, 1973, you proposed a change in the Technical Specifications of Facility License No. DR-15 to remove the requirement for intrusion alarm sensors on the perimeter fence while retaining requirements for alarm sensors at other locations. Based on our review of the proposed change, we have concluded that implementation of the change will not present significant hazards considerations not described or implicit in the Safety Analysis Report and that there is reasonable assurance that the health and safety of the public will not be endangered. Accordingly, pursuant to Section 50.59 of 10 CFR Part 50, the Technical Specifications of Facility License No. DR-15 are changed by deleting item 3.2-a.

Sincerely,

Donald J. Skovholt  
Assistant Director for  
Operating Reactors  
Directorate of Licensing

cc: David Sherman, Counsel  
Breeder Reactor Department  
General Electric Company  
310 DeGuligne Drive  
Sunnyvale, California 94086

A178

|         |               |        |           |            |  |  |
|---------|---------------|--------|-----------|------------|--|--|
| OFFICE  | L:OR-1        | L:OR-1 | L:OR-1    | L:OR       |  |  |
|         | x 7434        |        |           |            |  |  |
| SURNAME | PBErickson:dc | SAT:dc | RJSchemel | DJSkovholt |  |  |
| DATE    | 2/2/73        | 2/2/73 | 2/6/73    | 2/6/73     |  |  |