



SOUTHERN CALIFORNIA
EDISON

An EDISON INTERNATIONAL Company

Dwight E. Nunn
Vice President

June 18, 1997

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555

Gentlemen:

Subject: Docket Nos. 50-361 and 50-362
Diesel Generator Testing
Proposed Technical Specification Change Number NPF-10/15-478
San Onofre Nuclear Generating Station
Units 2 and 3

- References: (1) Letter, J. L. Rainsberry to U.S. Nuclear Regulatory Commission, Document Control Desk, Subject: "Diesel Generator Testing, San Onofre Nuclear Generating Station, Units 2 and 3," dated March 21, 1997.
- (2) NUREG-1432, "Standard Technical Specifications, Combustion Engineering Plants (CEOG STS)," September, 1992
- (3) Letter, Dwight E. Nunn to U. S. Nuclear Regulatory Commission, Document Control Desk, Subject: "Proposed Technical Specification Change Number 483, San Onofre Nuclear Generating Station, Units 2 and 3," dated April 15, 1997
- (4) Letter, Dwight E. Nunn to U. S. Nuclear Regulatory Commission, Document Control Desk, Subject: "Proposed Technical Specification Change Number 477, San Onofre Nuclear Generating Station, Units 2 and 3," dated January 24, 1997
- (5) Letter, Dwight E. Nunn to U. S. Nuclear Regulatory Commission, Document Control Desk, Subject: "ESF Timing Technical Specification Change NPF-10/15-454, Proposed Technical Specification Change Number 454, San Onofre Nuclear Generating Station, Units 2 and 3," dated May 29, 1996
- 11
A201

9706240010 970618
PDR ADOCK 05000361
P PDR

P. O. Box 128
San Clemente, CA 92674-0128
714-368-1480
Fax 714-368-1490



Enclosed are Amendment Application Numbers 168 and 154 to Facility Operating Licenses NPF-10 and NPF-15, respectively, for San Onofre Nuclear Generating Station (SONGS), Units 2 and 3. The Amendment Application consists of Proposed Technical Specification Change Number NPF-10/15-478 (PCN-478).


The proposed change is requested to revise Technical Specification (TS) 3.8.1, "AC Sources - Operating" and applicable Bases. This change will more clearly reflect safety analysis and testing conditions. This PCN does not address changes to Surveillance Requirements 3.8.1.8, 3.8.1.9, and 3.8.1.18 which were previously addressed by References 3, 4 and 5. In addition a Supplement to PCN 454 (Reference 5) will be submitted by August 1, 1997.

As mentioned in Reference 1 and prior correspondence on this issue, the change is based on a re-review of our implementation of Technical Specification Implementation Program (TSIP).

The Southern California Edison Company requests this amendment be issued effective as of its date of issuance, to be implemented within 30 days from the date of issuance.

If you would like additional information on this Amendment Application, please let me know.

Sincerely,

A handwritten signature in dark ink, appearing to read "Dwight E. Perkins", followed by a long horizontal flourish.

Enclosures

cc: E. W. Merschhoff, Regional Administrator, NRC Region IV
K. E. Perkins, Jr., Director, Walnut Creek Field Office, NRC Region IV
J. A. Sloan, NRC Senior Resident Inspector, San Onofre Units 2 and 3
M. B. Fields, NRC Project Manager, San Onofre Units 2 and 3