

ENCLOSURE

U.S. NUCLEAR REGULATORY COMMISSION
REGION IV

Docket No.: 50-361
50-362

Licenses No.: NPF-10
NPF-15

Report No.: 50-361;-362/97-07

Licensee: Southern California Edison Co.

Facility Name: San Onofre Nuclear Generating Station, Units 2 and 3

Location: Camp Pendleton, California

Dates: April 7-11, 1997

Inspector: Bruce Earnest, Physical Security Specialist, Plant Support Branch

Approved By: Blaine Murray, Chief, Plant Support Branch
Division of Reactor Safety

ATTACHMENT: Supplemental Information

DOCUMENT CONTAINS
SAFEGUARDS INFORMATION

9705160048 970509
PDR ADDCK 05000361
Q PDR

ENCLOSURE CONTAINS
SAFEGUARDS INFORMATION
UPON SEPARATION THIS
PAGE IS DECONTROLLED

EXECUTIVE SUMMARY

San Onofre Nuclear Generating Station, Units 2 & 3
NRC Inspection Report 50-361;-362/97-07

This routine, announced inspection focused on the licensee physical security program. The areas inspected included review of personnel access control, security organization, protected area barriers, protected area detection, training and qualifications, assessment aids, plans and procedures, vital area barriers, and vital area detection.

Plant Support

- Personnel access to the protected area was properly controlled (Section S1.1).
- An adequate security organization was in place and capable of meeting security and contingency plan requirements (Section S1.2).
- The inspector identified weaknesses in portions of the protected area barrier (Section S1.3).
- An effective perimeter detection system was installed and maintained (Section S1.4).
- The training and qualification program for security officers was effective (Section S1.5).
- The assessment aids system provided adequate assessment of the perimeter detection zones (Section S1.6).
- The security procedures contained provisions that did not accurately reflect physical security plan requirements (Section S1.7).
- An adequate vital area barrier system was in place (Section S1.8).
- The vital area detection aids were adequate to detect an intruder attempting to enter the vital areas (Section S1.9).

DOCUMENT CONTAINS
SAFEGUARDS INFORMATION

ENCLOSURE CONTAINS
SAFEGUARDS INFORMATION
UPON SEPARATION THIS
PAGE IS DECONTROLLED