



Point Beach Nuclear Plant
6610 Nuclear Rd., Two Rivers, WI 54241

(414) 755-2321

NPL 97-0364

June 19, 1997

Document Control Desk
U.S. NUCLEAR REGULATORY COMMISSION
Mail Station P1-137
Washington, D. C. 20555

Ladies/Gentlemen:

DOCKETS 50-266 AND 50-301
LICENSEE EVENT REPORT 97-026-00
TECHNICAL SPECIFICATION VIOLATION OF
OPERABILITY REQUIREMENT FOR MAIN STEAM LINE ISOLATION
POINT BEACH NUCLEAR PLANT, UNITS 1 AND 2

Enclosed is Licensee Event Report 97-026-00 for Point Beach Nuclear Plant, Units 1 and 2. This report is provided in accordance with 10 CFR 50.73(a)(2)(i)(B), "Any operation or condition prohibited by the plant's Technical Specifications." This report describes the identification of the failure to establish operability of the reactor coolant system average temperature instrumentation input to the main steam line isolation function during plant conditions required by Technical Specification Table 15.3.5-4 item 2.b operability requirements.

New commitments within the report are indicated in italics.

Please contact us if you require additional information.

Sincerely,

A handwritten signature in dark ink, appearing to read 'D. F. Johnson'.

D. F. Johnson
Manager - Regulatory Services & Licensing

IE221

Enclosure

cc: NRC Resident Inspector
NRC Regional Administrator
PSCW

9706250076 970619
PDR ADOCK 05000266
S PDR

