



Illinois Power Company  
Clinton Power Station  
P.O. Box 678  
Clinton, IL 61727  
Tel 217 935-8220  
Fax 217 935-4632

Wayne D. Romberg  
Assistant Vice President - Nuclear

U-602758

2C.220

June 18, 1997

Docket No. 50-461

10CFR50.73

Document Control Desk  
Nuclear Regulatory Commission  
Washington, D.C. 20555

Subject: Clinton Power Station - Unit 1  
Licensee Event Report No. 97-014-00

Dear Madam or Sir:

Enclosed is Licensee Event Report (LER) No. 97-014-00: Main Steam Isolation Valves (MSIVs) Closure Time Outside of Technical Specifications Due to Procedural Inadequacy. This report is being submitted in accordance with the requirements of 10CFR50.73.

The enclosure to this letter contains the following commitments:

- Clinton Power Station procedure 9061.09 will be revised to account for full valve travel.
- Operations personnel will be trained on the MSIV limit switch configuration and how it affects the position indicating lights in the Main Control Room.
- An engineering evaluation was performed on the most recent MSIV closure results performed May 20, 1997. The evaluation determined that one of the eight MSIVs did not meet TS requirements. This MSIV's stroke time will be adjusted and the valve will be retested to verify TS operability before plant start up.

9706250242 970618  
PDR ADOCK 05000461  
S PDR

250052



FE221

If any additional information is required on this subject, please contact J. V. Sipek, Director-Licensing, at (217) 935-8881, extension 3405 or J. C. Allen, Senior Engineer, at (217) 935-8881, extension 4046.

Sincerely yours,

A handwritten signature in cursive script, appearing to read "Wayne D. Romberg".

Wayne D. Romberg  
Assistant Vice President

JRF/krk

Enclosure

cc: NRC Clinton Licensing Project Manager  
NRC Resident Office, V-690  
Regional Administrator, Region III, USNRC  
Illinois Department of Nuclear Safety  
INPO Records Center