

May 14, 1997

LICENSEE: THE CLEVELAND ELECTRIC ILLUMINATING COMPANY

FACILITY: PERRY NUCLEAR POWER PLANT, UNIT 1

SUBJECT: SUMMARY OF MEETING HELD ON MAY 8, 1997, TO DISCUSS GENERAL
LICENSING ISSUES

On May 8, 1997, NRC staff members met at Rockville, Maryland, with representatives of The Cleveland Electric Illuminating Company (CEI) to discuss priorities and schedules of licensing issues for the Perry Nuclear Power Plant, Unit 1. A list of attendees is included as Enclosure 1. The handout used at the meeting is included as Enclosure 2.

Schedules were reviewed regarding the need for a licensing decision prior to the refueling outage commencing in September 1997. Additionally, the schedule of June 1, 1997, was discussed regarding the proposed indirect transfer of license caused by the planned merger of Centerior Energy Corporation and Ohio Edison Company. The NRC staff stated that they would inform CEI of any schedule delays regarding the proposed indirect transfer, if they occurred.

Original signed by:

Jon B. Hopkins, Senior Project Manager
Project Directorate III-3
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Docket No. 50-440

Enclosures: As stated

cc w/encls: See next page

NRC FILE CENTER COPY

DISTRIBUTION:

Hard Copy w/encls:

Docket File

PUBLIC

PD3-3 R/F

OGC

ACRS

GGrant, RIII

200104

E-Mail w/encl 1:

SCollins (SJCJ)

FMiraglia (FJA)

TMartin (TTM)

RZimmerman (RPZ)

JRoe (JWR)

EAdensam (EGA1)

BMcCabe (BCM)

GMarcus (GHM)

DRoss (SAM)

DOCUMENT NAME: G:\PERRY\MTGSUM.508

OFFICE	PDIII-3:LA	N	PDIII-3:PM	E
NAME	CBoyle		JHopkins	
DATE	05/14/97		05/14/97	

OFFICIAL RECORD COPY

9705210107 970514
PDR ADOCK 05000440
P PDR

dro1
111

May 14, 1997

LICENSEE: THE CLEVELAND ELECTRIC ILLUMINATING COMPANY

FACILITY: PERRY NUCLEAR POWER PLANT, UNIT 1

SUBJECT: SUMMARY OF MEETING HELD ON MAY 8, 1997, TO DISCUSS GENERAL
LICENSING ISSUES

On May 8, 1997, NRC staff members met at Rockville, Maryland, with representatives of The Cleveland Electric Illuminating Company (CEI) to discuss priorities and schedules of licensing issues for the Perry Nuclear Power Plant, Unit 1. A list of attendees is included as Enclosure 1. The handout used at the meeting is included as Enclosure 2.

Schedules were reviewed regarding the need for a licensing decision prior to the refueling outage commencing in September 1997. Additionally, the schedule of June 1, 1997, was discussed regarding the proposed indirect transfer of license caused by the planned merger of Centerior Energy Corporation and Ohio Edison Company. The NRC staff stated that they would inform CEI of any schedule delays regarding the proposed indirect transfer, if they occurred.

Original signed by:

Jon B. Hopkins, Senior Project Manager
Project Directorate III-3
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Docket No. 50-440

Enclosures: As stated

cc w/encls: See next page

DISTRIBUTION:

Hard Copy w/encls:

Docket File

PUBLIC

PD3-3 R/F

OGC

ACRS

GGrant, RIII

E-Mail w/encl 1:

SCollins (SJC1)

FMiraglia (FJM)

TMartin (TTM)

RZimmerman (RPZ)

JRoe (JWR)

EAdensam (EGA1)

BMcCabe (BCM)

GMarcus (GHM)

DRoss (SAM)

DOCUMENT NAME: G:\PERRY\MTGSUM.508

OFFICE	PDIII-3:LA	N	PDIII-3:PM	E
NAME	CBoyle		JHopkins	
DATE	05/14/97		05/14/97	

OFFICIAL RECORD COPY

Centerior Service Company

cc:

Jay E. Silberg, Esq.
Shaw, Pittman, Potts & Trowbridge
2300 N Street, N. W.
Washington, D. C. 20037

Mary E. O'Reilly
Centerior Energy Corporation
300 Madison Avenue
Toledo, Ohio 43652

Resident Inspector's Office
U. S. Nuclear Regulatory Commission
Parmly at Center Road
Perry, Ohio 44081

Regional Administrator, Region III
U. S. Nuclear Regulatory Commission
801 Warrenville Road
Lisle, Illinois 60532-4531

Lake County Prosecutor
Lake County Administration Bldg.
105 Main Street
Painesville, Ohio 44077

Sue Hiatt
OCRE Interim Representative
8275 Munson
Mentor, Ohio 44060

Terry J. Lodge, Esq.
618 N. Michigan Street, Suite 105
Toledo, Ohio 43624

Ashtabula County Prosecutor
25 West Jefferson Street
Jefferson, Ohio 44047

Henry L. Hegrat
Regulatory Affairs Manager
Cleveland Electric Illuminating Co.
Perry Nuclear Power Plant
P. O. Box 97, A210
Perry, Ohio 44081

James R. Williams
Chief of Staff
Ohio Emergency Management Agency
2855 West Dublin Granville Road
Columbus, Ohio 43235-2206

Lew W. Myers
Vice President - Nuclear, Perry
Centerior Service Company
P.O. Box 97, A200
Perry, Ohio 44081

Perry Nuclear Power Plant
Unit Nos. 1 and 2

Mayor, Village of Perry
4203 Harper Street
Perry, Ohio 44081

Donna Owens, Director
Ohio Department of Commerce
Division of Industrial Compliance
Bureau of Operations & Maintenance
6606 Tussing Road
P.O. Box 4009
Reynoldsburg, Ohio 43068-9009

Mayor, Village of North Perry
North Perry Village Hall
4778 Lockwood Road
North Perry Village, Ohio 44081

Attorney General
Department of Attorney General
30 East Broad Street
Columbus, Ohio 43216

Radiological Health Program
Ohio Department of Health
P.O. Box 118
Columbus, Ohio 43266-0118

Ohio Environmental Protection
Agency
DERR--Compliance Unit
ATTN: Mr. Zack A. Clayton
P.O. Box 1049
Columbus, Ohio 43266-0149

Chairman
Perry Township Board of Trustees
3750 Center Rd., Box 65
Perry, Ohio 44081

State of Ohio
Public Utilities Commission
East Broad Street
Columbus, Ohio 43266-0573

Richard D. Brandt, Plant Manager
Cleveland Electric Illuminating Co.
Perry Nuclear Power Plant
P.O. Box 97, SB306
Perry, Ohio 44081

Roy P. Lessy, Jr., Esq.
Andrew G. Berg, Esq.
Akin, Gump, Strauss, Hauer &
Feld, L.L.P.
Suite 400
1333 New Hampshire Avenue, NW.
Washington, D.C. 20036

NRC MEETING WITH THE CLEVELAND ELECTRIC ILLUMINATING COMPANY

PERRY NUCLEAR POWER PLANT, UNIT 1

LIST OF ATTENDEES

MAY 8, 1997

<u>NAME</u>	<u>ORGANIZATION</u>
J. Hopkins	NRC
G. Marcus	NRC
H. Hegrat	CEI
B. Ferrell	CEI
G. Rhoads	CEI

ENCLOSURE 1

RFO6/NRC

06-May-97

ISSUE	LETTER NUMBER	DATE SUBMITTED	BENEFIT/COMMENT	FRN
Containment and Fuel Handling Building Integrity	1995L	11/2/95	Allows relaxation of containment and fuel building integrity after 7 days of radioactive decay.	
Performance Based Drywell Bypass Leak Rate Test	2007L	1/16/96	Permits performance based test intervals for drywell bypass leak rate test	7/2/96
Elimination of MSIV-LCS and Increase in Main Steam Line leakage limits using Revised Accident Source	2076L	8/27/96	Would eliminate the need for MSIV-LCS system, and would permit Main Steam line leak rates to increase to 100 scfh for any line as long as all four lines are less than 250 scfh	
Thermo-Lag	2091L	10/2/96	Will need new letter dealing with Thermo-Lag involved with MSIV-LCS due to not getting RAST amendment	
MCPR Safety Limit	2104L	10/24/96	Will need to permit start up following RFO6 due to new fuel being installed.	2/12/97

ENCLOSURE 2

NC 1973 **CE CENTERIOR ENERGY** 2 of pages 3

To J. Hopkins	From G. Rhoads
Co NRC	Co Perry Nuclear
Dept.	Phone # 216-250-5299
Ext.	Fax #

Operating Companies:

Cleveland Electric Illuminating • Toledo Edison

ISSUE	LETTER NUMBER	DATE SUBMITTED	BENEFIT/COMMENT	ERN
ECCS Suction Strainer	2111L	11/4/96	May need additional response letter to answer NRC concerns	
ASME Code Cases N498-1, N522, and N546	2125L	1/7/97	Addresses relief from various tests to delete duplication, and also eliminates some inspection qualification requirements	
Performance Based Containment Leak Testing - Option B	2133L	1/31/97	Permits performance based test intervals for Type A, B, and C testing	3/12/97
ISI Relief Requests	2068L/2136L	2/12/97	Relief from Code requirements for the first 10 year interval - would require disassembly of various class 1 valves and recirculation jet shields	
Fuel Handling SR extensions	2155L	4/9/97	Changes Channel Functional Test (CFT) requirements from 7 to 14 days	

ISSUE	LETTER NUMBER	DATE SUBMITTED	BENEFIT/COMMENT	FRN
Main Steam Line leakage limit increase (35 scfh/main steam line - 100scfh total)	2165L	5/2/97	Will need because we are not getting the RAST amendment	
MSIV-LCS 3.0.4 exception	2164L	5/2/97	Will need because we are not getting the RAST amendment	

AK Team Insp.