

## PRECURSOR DESCRIPTION SHEET

LER No.: 237/85-044  
Event Description: Unavailability of Emergency Power  
Date of Event: December 13, 1985  
Plant: Dresden 2

### EVENT DESCRIPTION

#### Sequence

The power cable to the Unit 2 swing diesel generator (DG 2/3) cooling water pump was found damaged during a routine inspection. It is believed personnel inadvertently damaged the cable by standing on a connector box, thus wearing away the sheathing and causing a burnout. The Unit 3 dedicated DG was tested and failed in test because of a failed bearing in the turbocharger and a bent shaft. A Unit 2 shutdown was initiated at 0610 h. At 1400 h the shutdown was canceled when DG 2/3 was returned to service.

#### Corrective Action

The swing DG 2/3 was repaired expeditiously and restored to service.

#### Plant/Event Data

Systems Involved:  
Emergency power

Components and Failure Modes Involved:  
DG 2/3 cable — failed in operation  
DG 3 bearing — failed in test

Component Unavailability Duration: Unknown, 360 h assumed  
Plant Operating Mode: 1 (100% power)  
Discovery Method: Testing and inspection  
Reactor Age: 15.0 years  
Plant Type: BWR

#### Comments

None

Event Identifier: 237/85-044

## MODELING CONSIDERATIONS AND DECISIONS

### Initiators Modeled and Initiator Nonrecovery Estimate

LOOP (postulated      Base case  
event)

### Branches Impacted and Branch Nonrecovery Estimate

Emergency power	1.0	Not considered restorable within 30 min
-----------------	-----	---

### Plant Models Utilized

BWR plant Class B

Event Identifier: 237/85-044

# CONDITIONAL CORE DAMAGE CALCULATIONS

LER Number: 237/85-044  
 Event Description: Unavailability of Emergency Power  
 Event Date: 12/13/85  
 Plant: Dresden 2

UNAVAILABILITY, DURATION= 360

## NON-RECOVERABLE INITIATING EVENT PROBABILITIES

LOOP	1.597E-03
------	-----------

## SEQUENCE CONDITIONAL PROBABILITY SUMS

End State/Initiator	Probability
CV	
LOOP	( 3.369E-08 )
Total	( 3.369E-08 )
CD	
LOOP	3.203E-06
Total	3.203E-06
ATWS	
LOOP	6.199E-07
Total	6.199E-07

## DOMINANT SEQUENCES

End State: CD	Conditional Probability: 1.783E-06
238 LOOP EMERG.POWER -SCRAM SRV.CHALL/LOOP.-SCRAM -SRV.CLOSE ISOL.COND HPCI	
End State: ATWS	Conditional Probability: 6.522E-07
243 LOOP EMERG.POWER SCRAM	

## SEQUENCE CONDITIONAL PROBABILITIES

Event Identifier: 237/85-044

	Sequence	End State	Seq. Prob	Non-Recov**
238	LOOP EMERG.POWER -SCRAM SRV.CHALL/LOOP.-SCRAM -SRV.CLOSE IS OL.COND HPCI	CD	1.783E-06 *	1.938E-01
240	LOOP EMERG.POWER -SCRAM SRV.CHALL/LOOP.-SCRAM SRV.CLOSE HP CI	CD	1.495E-06	1.938E-01
243	LOOP EMERG.POWER SCRAM	ATWS	6.522E-07 *	3.400E-01

\* dominant sequence for end state

\*\* non-recovery credit for edited case

#### Note:

Conditional probability values are differential values which reflect the added risk due to observed failures. Parenthetical values indicate a reduction in risk compared to a similar period without the existing failures.

MODEL: b:bwrmtree.cmp

DATA: b:drprob.cmp

No Recovery Limit

#### BRANCH FREQUENCIES/PROBABILITIES

Branch	System	Non-Recov	Opr Fail
TRANS	1.142E-03	1.000E+00	
LOOP	1.305E-05	3.400E-01	
LOCA	3.250E-06	3.400E-01	
SCRAM	4.100E-04	1.000E+00	
SLC.OR.RODS	1.000E-02	1.000E+00	4.000E-02
PCS/TRANS	1.700E-01	1.000E+00	
PCS/LOCA	1.000E+00	1.000E+00	
SRV.CHALL/TRANS.-SCRAM	1.000E+00	1.000E+00	
SRV.CHALL/TRANS.SCRAM	1.000E+00	1.000E+00	
SRV.CHALL/LOOP.-SCRAM	1.000E+00	1.000E+00	
SRV.CHALL/LOOP.SCRAM	1.000E+00	1.000E+00	
SRV.CLOSE	1.650E-02	1.000E+00	
EMERG.POWER	2.850E-03 > 1.000E+00 ***	5.100E-01 > 1.000E+00	
Branch Model: 1.OF.2			
Train 1 Cond Prob:	5.000E-02		
Train 2 Cond Prob:	5.700E-02		
FW/PCS.TRANS	2.900E-01	3.400E-01	
FW/PCS.LOCA	4.000E-02	3.400E-01	
HPCI	1.000E-01	5.700E-01	
ISOL.COND	2.000E-02	1.000E+00	
CRD	1.000E-02	1.000E+00	4.000E-02
SRV.ADS	6.700E-03	1.000E+00	4.000E-02
COND/FW.PCS	1.000E+00	3.400E-01	
LPCS	2.000E-03	3.400E-01	
LPCI	1.000E-03	3.400E-01	
FIREWTR.OR.OTHER/LPCS.LPCI/TRA	1.000E+00	1.000E+00	

Event Identifier: 237/85-044

FIREWTR. OR. OTHER/LPCS.LPCI/LDD	1.000E+00	1.000E+00
FIREWTR. OR. OTHER/LPCS.LPCI/LDC	1.000E+00	1.000E+00
SDC	2.898E-03	3.400E-01
LPCI(CC)	1.000E-03	3.400E-01
LPCI(CC)/LPCI	1.000E+00	1.000E+00
C.I.AND.V/LPCI	1.000E+00	3.400E-01

\*\*\* forced

Austin  
08-14-1986  
12:45:28

Event Identifier: 237/85-044