

UNITED STATES NUCLEAR REGULATORY COMMISSIONDOCKET NOS. 50-295 AND 50-304COMMONWEALTH EDISON COMPANYNOTICE OF ISSUANCE OF AMENDMENTS TO FACILITY
OPERATING LICENSES

The U. S. Nuclear Regulatory Commission (the Commission) has issued Amendment Nos. 40 and 37 to Facility Operating Licenses Nos. DPR-39 and DPR-48 issued to Commonwealth Edison Company (the licensee) which revised Technical Specifications for operation of the Zion Station Unit Nos. 1 and 2, located in Zion, Illinois. The amendments are effective as of the date of issuance.

These amendments allow the boron concentration in the pressurizer to be 200 ppm less than the reactor coolant loop boron concentration. These amendments also make two corrections in the Technical Specifications regarding the Isolation Valve Seal Water System and the Penetration Pressurization Systems.

The application for these amendments complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the license amendments. Prior public notice of these amendments was not required since the amendments do not involve a significant hazards consideration.


- 2 -

The Commission has determined that the issuance of these amendments will not result in any significant environmental impact and that pursuant to 10 CFR 51.5(d)(4) an environmental impact statement, or negative declaration and environmental impact appraisal need not be prepared in connection with issuance of these amendments.

For further details with respect to this action, see (1) the application for amendments dated May 24, 1977 as supplemented September 27, 1978, (2) Amendment Nos. 40 and 37 to License Nos. DPR-39 and DPR-48, and (3) the Commission's related Safety Evaluation. All of these items are available for public inspection at the Commission's Public Document Room, 1717 H Street, NW, Washington, D. C. 20555, Attention: Director, Division of Operating Reactors.

Dated at Bethesda, Maryland, this 30th day of November, 1978

FOR THE NUCLEAR REGULATORY COMMISSION



A. Schwencer, Chief
Operating Reactors Branch #1
Division of Operating Reactors