



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

~~CONFIDENTIAL~~ PDR

November 15, 1978

50-309

TO ALL PRESSURIZED WATER REACTOR LICENSEES

Gentlemen:

In a letter from B. Grimes, Assistant Director for Engineering and Projects, dated July 11, 1978, you were sent guidance and a submittal schedule which requested a license amendment application to be submitted to incorporate the requirements of 10 CFR Part 50, Appendix I into your facility Technical Specifications. Since that time, the staff has continued its efforts to simplify the specifications through clarification of intent and the removal of unnecessary requirements. In conjunction with these efforts we have had a number of discussions with the AIF and others concerning comments and questions they developed with respect to the specifications. As a result of our continuing review, we have made substantive revisions to the Draft Radiological Effluent Technical Specifications (NUREG-0472, PWR and NUREG-0473, BWR), which were forwarded to you in July. Although these specifications have been extensively revised, they still incorporate the fundamental requirements and concepts contained in the original documents. The major difference in these specifications from the previous ones is the removal from the specifications of the equations for dose calculations, setpoint determination and meteorological dispersion factors. These items, along with some miscellaneous items, are now required to be included in an Offsite Dose Calculation Manual (ODCM) to be prepared by the licensee and provided to NRC for review and approval along with your proposed Technical Specifications.

To assist you in preparing your submittal, we have enclosed a copy of Revision 1 of the Draft Radiological Effluent Technical Specifications. We have also enclosed for your use a copy of NUREG-0133, Preparation of Radiological Effluent Technical Specifications for Nuclear Power Plants. This NUREG document describes methods acceptable to the staff for the calculation of certain key values required in the preparation of the proposed effluent Technical Specifications.

In order to provide additional time to address this guidance, you may use the revised submittal schedule shown in Table I. The submittal dates are referenced to the date of this letter.


7812190042

In addition to the guidance noted above, the following general information is also provided:

- 1) The format for the revised Technical Specifications may be that presently used for your existing Appendix A Technical Specifications, provided all applicable areas of the model Technical Specifications are acceptably addressed. Although the staff recommends the format of the model Technical Specifications, its use is not mandatory.
- 2) It has been misinterpreted by several licensees that the Technical Specification submittal need only address the individual dose design objectives of Appendix I. The submittal request must implement 10 CFR Part 50, Section 50.36a, Technical Specifications on Effluents from Nuclear Power Reactors which addresses the maintenance and use of radwaste equipment installed pursuant to Section 50.34a(a), Section 50.34a which addresses Appendix I (Design Objectives IIA, IIB, IIC and IID), 10 CFR Part 20, 10 CFR Part 50, Appendix A, General Design Criteria 60 and 64 which address the control and monitoring of releases of radioactive material to the environment, and 40 CFR Part 190, Uranium Fuel Cycle Standard. Consequently, the NRC expects the submittals to reflect these and other issues addressed in the Draft Radiological Effluent Technical Specifications enclosed with this letter.
- 3) The submittal should consolidate the radiological effluent and environmental monitoring Technical Specifications in Appendix A of the Technical Specifications. Consequently, if your facility presently has radiological effluent or radiological environmental monitoring Technical Specifications in Appendix B, you should request that they be deleted upon approval of the new Technical Specifications in Appendix A. The submittal should resolve all duplicative Technical Specification requirements in the radiological area.
- 4) The entire Administrative Controls Section (6.0) of the Standard Technical Specifications was included for information. Only those areas related to radiological effluents and environmental monitoring need be considered for inclusion into the license amendment request. However, if you desire to convert your entire Administrative Controls Section to incorporate the STS requirements and format the staff could handle this as a separate request.

To further assist you in the preparation of your submittal the NRC will conduct a one-day seminar on the Draft Radiological Effluent Technical Specifications at four of our Regional Offices. The dates and locations of the seminars are shown in Table II. Representatives from the Office of Nuclear Reactor Regulation will make the presentation and the agenda will include an introduction and background on the effluent Technical Specifications, the development of the Standard Technical Specifications, and the method and schedule for implementing the specifications. A question and answer period will follow the prepared presentation. More specific information relative to these seminars will be forthcoming from our Regional Directors.

Sincerely,

A handwritten signature in dark ink, appearing to read "Brian K. Grimes". The signature is fluid and cursive, with the first name "Brian" being more prominent than the last name "Grimes".

Brian K. Grimes, Assistant Director
for Engineering and Projects
Division of Operating Reactors

Enclosures:

1. Tables I & II
2. Draft Radiological Effluent
Technical Specifications - PWR
3. NUREG-0133

TABLE I
RADIOLOGICAL EFFLUENT TECHNICAL SPECIFICATIONS
LICENSEE SUBMITTAL DATES

30 Days	60 Days	90 Days	120 Days
Farley	Big Rock Point	Arkansas	Beaver Valley
Hatch	Ginna	Brunswick	Browns Ferry
	Haddam Neck	Crystal River	Calvert Cliffs
	La Crosse	Dresden	Cook
	Oyster Creek	Fitzpatrick	Cooper
	San Onofre	Indian Point	Davis Besse
	Surry	Millstone	Duane Arnold
	Yankee Rowe	Monticello	Fort Calhoun
		Nine Mile Point	Humboldt Bay
		Oconee	Kewaunee
		Peach Bottom	Maine Yankee
		Pilgrim	North Anna
		Quad Cities	Palisades
		Robinson	Point Beach
		Turkey Point	Prarie Island
		Vermont Yankee	Rancho Seco
		Zion	Salem
			St. Lucie
			Three Mile Island
			Trojan

TABLE II

REGIONAL SEMINARS ON
DRAFT RADIOLOGICAL EFFLUENT TECHNICAL SPECIFICATIONS

November 28, 1978 - Region III

December 1, 1978 - Region IV & V (In Region V)

December 5, 1978 - Region II

December 8, 1978 - Region I

Yankee Atomic Electric Company

cc:

E. W. Thurlow, President
Maine Yankee Atomic Power Company
9 Green Street
Augusta, Maine 04330

Mr. Robert R. Radcliffe
Office of Energy Resources
55 Capitol Street
Augusta, Maine 04330

Mr. Donald E. Vandenburg
Vice President - Engineering
Yankee Atomic Electric Company
20 Turnpike Road
Westboro, Massachusetts 01581

John A. Ritscher, Esquire
Ropes and Gray
225 Franklin Street
Boston, Massachusetts 02110

Mr. John M. R. Paterson
Assistant Attorney General
State of Maine
Augusta, Maine 04330

Harold P. Green, Esquire
Suite 1000
The Watergate
600 New Hampshire Avenue, N.W.
Washington, D.C. 20037

Mr. Nicholas Barth
Executive Director
Sheepscot Valley Conservation
Association, Inc.
P. O. Box 125
Alna, Maine 04535

Wiscasset Public Library Association
High Street
Wiscasset, Maine 04578

Mrs. L. Patricia Doyle, President
SAFE POWER FOR MAINE
Post Office Box 774
Camden, Maine 04843