

CONTROL BLOCK: 

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	I L Z I S 1												2	0	0	-	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5																			
7	8	L I C E N S E E C O D E												14	L I C E N S E N U M B E R												25	L I C E N S E T Y P E												30	C A T												58

CON'T

0	1	L												6	0	5	0	0	0	2	9	5	7	0	8	2	2	7	8	8	0	9	2	1	7	8	9																
7	8	R E P O R T S O U R C E												60	D O C K E T N U M B E R												68	E V E N T D A T E												74	R E P O R T D A T E												80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | While performing maintenance activities, instru. dept. found xmtr 1FT-446

0 3 | failed at 103%. This is non-conservative for a 10 RC flow Rx trip

0 4 | (T.S. table 3.1-1). Redundant channels were operable, and available so

0 5 | the health and safety of the public was not affected.

0 6 |

0 7 |

0 8 |

7 8 9

SYSTEM CODE I A 11		CAUSE CODE E 12		CAUSE SUBCODE E 13		COMPONENT CODE I N S T R U 14				COMP. SUBCODE T 15		VALVE SUBCODE Z 16	
7 8		17 LER/RO REPORT NUMBER		EVENT YEAR 7 8		SEQUENTIAL REPORT NO. 0 8 4		OCCURRENCE CODE 0 3		REPORT TYPE L		REVISION NO. 0	
ACTION TAKEN A 18		FUTURE ACTION Z 19		EFFECT ON PLANT Z 20		SHUTDOWN METHOD Z 21		HOURS 0 0 0 0 22		ATTACHMENT SUBMITTED N 23		NPRD-4 FORM SUB. Y 24	
PRIME COMP. SUPPLIER N 25		COMPONENT MANUFACTURER F 1 2 0 26											

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The cause of the event was the failure of the oscillator in the

1 1 transmitter (Fisher-Porter model #10B2496). The defective oscillator was

1 2 replaced, the xmtr was recalibrated and the channel returned to service.

1 3 This has not been a repetitive problem. No further action is required.

1 4

FACILITY STATUS			% POWER			OTHER STATUS			METHOD OF DISCOVERY			DISCOVERY DESCRIPTION		
1	5	E	0	6	2	NA			B	Instrument Maintenance Surv.				
7	8	9	10	12	13	44			45	46	80			
ACTIVITY CONTENT			RELEASED OF RELEASE			AMOUNT OF ACTIVITY			LOCATION OF RELEASE					
1	6	Z	Z	NA			NA							
7	8	9	10	11	44			45	80					
PERSONNEL EXPOSURES			NUMBER			TYPE			DESCRIPTION					
1	7	0	0	0	Z	NA								
7	8	9	11	12	13	44			80					
PERSONNEL INJURIES			NUMBER			DESCRIPTION								
1	8	0	0	0	NA									
7	8	9	11	12	44			80						
LOSS OF OR DAMAGE TO FACILITY			TYPE			DESCRIPTION								
1	9	Z	NA											
7	8	9	10	44			80							
PUBLICITY			ISSUED			DESCRIPTION			NRC USE ONLY					
2	0	N	NA											
7	8	9	10	44			80							

NRC USE ONLY

X-244