LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

1 | G A S I H 2 (2) | 0 0 0 0 0 0 0 0 0 0 0 (3) | 4 1 1 1 1 (4) | (5)
8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

CON'T
1 | REPORT SOURCE L (6) | 0 5 0 0 0 3 6 6 (7) | 0 9 2 0 7 8 (8) | 1 0 0 5 7 8 (9)
8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

2 | On 9-20-78 at 1400 during a review of NRC commitments it was discovered that the
3 | commitment relating to Fire Team Training had not been met. Consequences are not
4 | considered to be significant in that the personnel involved have received prior
5 | training in Fire Protection and are knowledgeable in plant areas and procedures
6 | applicable to their duties as Fire Team Members.
7 |
8 |
9 |

SYSTEM CODE Z Z (11) | CAUSE CODE X (12) | CAUSE SUBCODE X (13) | COMPONENT CODE Z Z Z Z Z Z (14) | COMP. SUBCODE Z (15) | VALVE SUBCODE Z (16)
9 10 11 12 13 18 19 20

(17) LER/RO REPORT NUMBER: EVENT YEAR 7 8 (21 22) | — (23) | SEQUENTIAL REPORT NO. 0 3 8 (24 26) | / (27) | OCCURRENCE CODE 0 3 (28 29) | REPORT TYPE L (30) | — (31) | REVISION NO. 0 (32)

ACTION TAKEN X (18) | FUTURE ACTION Z (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS (22) 0 0 0 0 (37 40) | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. N (24) | PRIME COMP. SUPPLIER Z (25) | COMPONENT MANUFACTURER Z 9 9 9 (26)
33 34 35 36 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 | Working in HNP Fire Evaluation Commitments and verbal commitment made to NRC in April
11 | 1978 are not consistent corrective action will be to have Fire Team Members review
12 | procedures as referenced in the evaluation by 11/4/78. Documentation of this review
13 | will be filed in Training Records
14 |

FACILITY STATUS C (28) | % POWER 0 0 1 (29) | OTHER STATUS (30) N/A | METHOD OF DISCOVERY A (31) | DISCOVERY DESCRIPTION (32) Review of HNP Fire Evaluation
8 9 10 12 13 44 45 46 80

ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) N/A | LOCATION OF RELEASE (36) N/A
8 9 10 11 44 45 80

PERSONNEL EXPOSURES NUMBER 0 0 0 (37) | TYPE Z (38) | DESCRIPTION (39) N/A
8 9 11 12 13 80

PERSONNEL INJURIES NUMBER 0 0 0 (40) | DESCRIPTION (41) N/A
8 9 11 12 80

LOSS OF OR DAMAGE TO FACILITY (43) TYPE Z (42) | DESCRIPTION N/A
8 9 10 80

PUBLICITY ISSUED N (44) | DESCRIPTION (45) N/A | NRC USE ONLY
8 10 68 69 80

7810180026

NAME OF PREPARER T. V. Greene, Supt. of Eng. Services PHONE (912) 367-7781