

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK:										(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)									
<div style="display: flex; justify-content: space-between;"> 0 1 C A R S S 1 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5 </div>										<div style="display: flex; justify-content: space-between;"> L 6 0 5 0 0 0 3 1 2 7 0 9 1 3 7 8 8 1 0 1 6 7 8 9 </div>									
<div style="display: flex; justify-content: space-between;"> REPORT SOURCE DOCKET NUMBER EVENT DATE REPORT DATE </div>																			
EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)																			
During steady state power operation on September 13, 1978, the dissolved																			
oxygen concentration downstream of the confluence of Hadselville and																			
Clay Creek was less than the minimum 5 mg/liter required by Technical																			
Specification Appendix B, Section 2.5 A.																			
<div style="display: flex; justify-content: space-between;"> SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE </div>																			
<div style="display: flex; justify-content: space-between;"> W 11 C 12 Z 13 Z Z Z Z Z Z 14 Z 15 Z 16 </div>																			
<div style="display: flex; justify-content: space-between;"> LER/RO REPORT NUMBER EVENT YEAR SEQUENT. REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO. </div>																			
<div style="display: flex; justify-content: space-between;"> 7 8 7 8 0 0 3 0 4 T 0 </div>																			
<div style="display: flex; justify-content: space-between;"> ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPRD-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER </div>																			
<div style="display: flex; justify-content: space-between;"> H 18 G 19 Z 20 Z 21 0 0 0 0 Y 23 N 24 Z 25 Z 9 9 9 26 </div>																			
CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)																			
Low dissolved oxygen concentration is typical of stagnant water. Sample																			
location is beyond the District's property and the District has no control																			
of water flow at that point. The problem will be resolved with the																			
CRWQCB.																			
<div style="display: flex; justify-content: space-between;"> FACILITY STATUS % POWER OTHER STATUS METHOD OF DISCOVERY DISCOVERY DESCRIPTION </div>																			
<div style="display: flex; justify-content: space-between;"> E 28 1 0 0 NA B 31 Review of Chemistry Records. </div>																			
<div style="display: flex; justify-content: space-between;"> ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY LOCATION OF RELEASE </div>																			
<div style="display: flex; justify-content: space-between;"> Z 33 Z 34 NA NA </div>																			
<div style="display: flex; justify-content: space-between;"> PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION </div>																			
<div style="display: flex; justify-content: space-between;"> 0 0 0 37 Z 38 NA </div>																			
<div style="display: flex; justify-content: space-between;"> PERSONNEL INJURIES NUMBER DESCRIPTION </div>																			
<div style="display: flex; justify-content: space-between;"> 0 0 0 40 NA </div>																			
<div style="display: flex; justify-content: space-between;"> LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION </div>																			
<div style="display: flex; justify-content: space-between;"> Z 42 NA </div>																			
<div style="display: flex; justify-content: space-between;"> PUBLICITY ISSUED DESCRIPTION </div>																			
<div style="display: flex; justify-content: space-between;"> Y 44 Local news media notified on October 11, 1978. </div>																			
NAME OF PREPARER										R.W. Colombo									
PHONE										(916) 452-3211									

7810200106