



THE CLEVELAND ELECTRIC ILLUMINATING COMPANY

P.O. BOX 97 ■ PERRY, OHIO 44081 ■ TELEPHONE (216) 259-3737 ■ ADDRESS-10 CENTER ROAD

Serving The Best Location in the Nation
PERRY NUCLEAR POWER PLANT

Al Kaplan

VICE PRESIDENT
NUCLEAR GROUP

March 3, 1988
PY-CEI/NRR-0818 L

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D. C. 20555

Perry Nuclear Power Plant
Docket No. 50-440
Technical Specification
Change Request Turbine Valve
Inspection Deferral


Gentlemen:

This letter supplements the Technical Specification Change Request letter (PY-CEI/NRR-0801L) dated February 10, 1988 concerning Turbine Valve Inspection deferrals.

Since the submittal of the original change request, a review of the work history of these valves determined that the valves were cleaned and installed into the plant between September 10, 1984 and November 15, 1984. The September 10, 1984 date corresponding to the start of this work is the appropriate starting point for the 40-month surveillance interval. Based on this starting date, the 40-month due date for the surveillance was recalculated to be February 2, 1988. Utilization of the maximum allowable Technical Specification 4.0.2.a extension results in an overdue date of December 8, 1988, rather than June 13, 1988 as provided in the previous letter. Although this overdue date is later than previously discussed, the need still exists for the requested one-time extension to the first refueling outage, scheduled for the first quarter of 1989. The technical analyses used in the attachment to the original submittal are still valid, along with the commitment to perform this surveillance during any extended outage of sufficient duration that may occur prior to the first refueling outage.

Should you have any questions, please feel free to call.

Very truly yours,


Al Kaplan
Vice President
Nuclear Group

AK: cab

~~Attachment/Enclosure~~

cc: K. Connaughton
T. Colburn
J. Harris (State of Ohio)

8803080048 880303
PDR ADOCK 05000440
P DCD

A047
1/0