

Georgia Power Company
333 Piedmont Avenue
Atlanta, Georgia 30308
Telephone 404 526-6526

Mailing Address:
Post Office Box 4545
Atlanta, Georgia 30302

L. T. Guwa
Manager Nuclear Safety
and Licensing



SL-4154
0783m
X7GJ17-V750

February 29, 1988

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

PLANT VOGTLE - UNIT 1
NRC DOCKET 50-424
OPERATING LICENSE NPF-68
SUPPLEMENT TO SUMMARY REPORT OF STARTUP TEST PROGRAM

Gentlemen:

Section 6.8.1.1 of the Vogtle Electric Generating Plant Unit 1 Technical Specifications requires Georgia Power Company (GPC) to submit a supplement to the summary report of plant startup and power escalation testing every three months until completion of the test program.

In our letter dated November 30, 1987 GPC identified three startup tests and the overall Power Ascension Test Sequence procedure (1-600-13) as outstanding. Since then, the final thermal expansion measurements have been evaluated and found acceptable. All acceptance criteria for the Thermal Expansion Test (1-600-11) were met and plant response was determined to be within allowable tolerances.

Data collected during the Dynamic Response Test (1-600-06) is undergoing final evaluation and will be reported in a later supplement to the startup report.

Testing of four radiation monitors within the Process and Effluent Radiation Monitoring System (PERMS) remains open. Resolution of these open items is in progress to allow closure of the PERMS Test (1-6SD-01). This will be reported in a later supplement to the startup report.

Following completion of the Dynamic Response Test (1-600-06) evaluation and resolution of PERMS Test (1-6SD-01) open items, the Power Ascension Test Sequence procedure will be completed, thus completing the startup test program for Vogtle Unit 1.

8803080051 880229
PDR ADOCK 05000424
P DCD

IE26
11

U. S. Nuclear Regulatory Commission
February 29, 1988
Page Two

Please contact this office if you have any questions.

Sincerely,



L. T. Gucwa

EMB/lm

c: Georgia Power Company
Mr. P. D. Rice
Mr. G. Bockhold, Jr.
GO-NORMS

U. S. Nuclear Regulatory Commission
Dr. J. N. Grace, Regional Administrator
Mr. J. B. Hopkins, Licensing Project Manager, NRR (2 copies)
Mr. J. F. Rogge, Senior Resident Inspector-Operations, Vogtle

0783m