

9
MAR 2 1988

Docket Nos. 50-325 and 50-324

DISTRIBUTION

Mr. E. E. Utley
Senior Executive Vice President
Power Supply and Engineering & Construction
Carolina Power & Light Company
Post Office Box 1551
Raleigh, North Carolina 27602

Dear Mr. Utley:

Docket Nos. 50-324/325
NRC PDR EAdensam GPA/PA
Local PDR PAnderson ARM/LFMB
PD21 r/f B Mozafari
TMurley ESylvester
OGC-WF ACRS (10)
FMiraglia EJordan
CRossi JPartlow
SVarga TBarnhart (4)
GLainas J. Rajan

SUBJECT: INSERVICE INSPECTION RELIEF REQUEST NO. RR-8, REV. 0, FUNCTIONAL
TESTING OF SNUBBERS - BRUNSWICK STEAM ELECTRIC PLANT (BSEP), UNITS
1 & 2 (TAC NOS. 63786/63787)

By letter dated August 19, 1987, Carolina Power and Light Company (CP&L) submitted additional information to supplement a letter dated June 4, 1987, concerning the Inservice Inspection (ISI) Program for Brunswick Steam Electric Plant, Units 1 & 2. Contained in the August 19, 1987 submittal was relief request RR-8 by which CP&L requested relief from certain Section XI ASME Code requirements related to the second 10-year interval ISI program. The NRC staff has acted on relief request RR-8 as an individual action so it would not impact the scope and duration of the current refueling outage.

Based on our review and on information provided by CP&L during a telephone conference on November 23, 1987, the NRC staff has provided an interpretation of Section XI of the ASME Boiler and Pressure Vessel Code in the enclosed Safety Evaluation (SE).

The SE supports the proposed testing plan for the functional testing of snubbers. The NRC staff has determined that the requested relief is not necessary because the proposed plan meets Section XI of the ASME Code requirements and complies with the requirements of Technical Specification 4.7.5.

Sincerely,

151
Elinor Adensam, Director
Project Directorate II-1
Division of Reactor Projects - I/II

Enclosure:
As stated

Miller
LA:PD21:DRPR
PAnderson
02/26/88

BRM
PE:PD21:DRPR
B Mozafari:aly
02/26/88

ES
PM:PD21:DRPR
ESylvester
02/26/88

Mr
BC:EMEB:DEST
LMarsh
02/26/88

X
OGC-WF
02/26/88

Adensam
D:PD21:DRPR
EAdensam
02/26/88

8803080108 880302
PDR ADOCK 05000324
P PDR

Mr. E. E. Utley
Carolina Power & Light Company

Brunswick Steam Electric Plant
Units 1 and 2

cc:

Mr. P. W. Howe
Vice President
Brunswick Nuclear Project
Box 10429
Southport, North Carolina 28461

Mr. C. R. Dietz
Plant General Manager
Brunswick Nuclear Project
Box 10429
Southport, North Carolina 28461

Mr. R. E. Jones, General Counsel
Carolina Power & Light Company
P. O. Box 1551
Raleigh, North Carolina 27602

Mr. H. A. Cole
Special Deputy Attorney General
State of North Carolina
Post Office Box 629
Raleigh, North Carolina 27602

Mr. Mark S. Calvert
Associate General Counsel
Carolina Power & Light Company
Post Office Box 1551
Raleigh, North Carolina 27602

Mr. Robert P. Gruber
Executive Director
Public Staff - NCUC
Post Office Box 29520
Raleigh, North Carolina 27626-0520

Mr. Christopher Chappell, Chairman
Board of Commissioners
Post Office Box 249
Bolivia, North Carolina 28422

Mrs. Chrys Baggett
State Clearinghouse
Budget and Management
116 West Jones Street
Raleigh, North Carolina 27603

Resident Inspector
U. S. Nuclear Regulatory Commission
Star Route 1
Post Office Box 208
Southport, North Carolina 28461

Regional Administrator, Region II
U. S. Nuclear Regulatory Commission
101 Marietta Street, Suite 2900
Atlanta, Georgia 30303

Mr. Dayne H. Brown, Chief
Radiation Protection Branch
Division of Facility Services
N. C. Department of Human Resources
701 Barbour Drive
Raleigh, North Carolina 27603-2008