

VIRGINIA ELECTRIC AND POWER COMPANY  
RICHMOND, VIRGINIA 23261

W. L. STEWART  
VICE PRESIDENT  
NUCLEAR OPERATIONS

March 3, 1988

United States Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, D.C. 20555

Serial No. 88-103  
NO/RMK:jmj  
Docket Nos. 50-338  
50-339  
License Nos. NPF-4  
NPF-7

Gentlemen:

VIRGINIA ELECTRIC AND POWER COMPANY  
NORTH ANNA POWER STATION UNITS 1 AND 2  
PROPOSED TECHNICAL SPECIFICATION CHANGES

Pursuant to 10CFR50.90, Virginia Electric and Power Company requests an amendment, in the form of changes to the Technical Specifications, to Operating License Nos. NPF-4 and NPF-7 for North Anna Power Station Units 1 and 2.

The proposed changes would modify the Limiting Condition for Operation and the surveillance requirements of Technical Specification 3/4.7.14 as follows.

- a. Add a new action statement "b" which requires the establishment and demonstration of operability of the backup fire suppression system when the diesel driven fire pump is inoperable for performance of the 18 month inspection (T.S. 4.7.14.1.2.c).
- b. Change surveillance requirement 4.7.14.1.2.c by deleting the phrase "during shutdown," and adding a reference to the new action statement "b."
- c. Add a footnote to surveillance requirements 4.7.14.1.1, 4.7.14.1.2, and 4.7.14.1.3 for Unit 2 which provides the clarification that the fire suppression system is common to Unit 1, and therefore, the surveillance need only be performed once per the defined interval.
- d. Correct a typographical error in action statement "a."


This request has been reviewed and approved by the Station Nuclear Safety and Operating Committee and the Safety Evaluation and Control Staff. It has been determined that this change does not present an unreviewed safety question as defined in 10CFR50.59 and does not involve a significant hazards consideration as defined in 10CFR50.92.

8803080114 880303  
PDR ADOCK 0500033B  
P FDR

A001  
1/1  
w/ check \$150  
#00499

We have evaluated this request in accordance with the criteria of 10CFR170.12.  
The application fee of \$150.00 is enclosed.

Very truly yours,



W. L. Stewart

Attachment

cc: U. S. Nuclear Regulatory Commission  
101 Marietta Street, N.W.  
Suite 2900  
Atlanta, GA 30323

Mr. J. L. Caldwell  
NRC Senior Resident Inspector  
North Anna Power Station

COMMONWEALTH OF VIRGINIA )  
 )  
CITY OF RICHMOND )

The foregoing document was acknowledged before me, in and for the City and Commonwealth aforesaid, today by W. L. Stewart who is Vice President - Nuclear Operations, of Virginia Electric and Power Company. He is duly authorized to execute and file the foregoing document in behalf of that Company, and the statements in the document are true to the best of his knowledge and belief.

Acknowledged before me this 3<sup>rd</sup> day of March, 1988.

My Commission expires: February 25, 1990.

Vicki L. Hull  
Notary Public

(SEAL)