



Log # TXX-88283
File # 10110
903.9
Ref. # 10CFR50.55(e)

William G. Council
Executive Vice President

March 1, 1988 - 07

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D.C. 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION (CPSES)
DOCKET NOS. 50-445 AND 50-446
TRAIN "C" CONDUIT SUPPORTS
SDAR: CP-85-36 (INTERIM REPORT)

Gentlemen:

On November 5, 1987, we notified you by our letter logged TXX-6928 of a deficiency involving the installation of non-safety related conduit (two-inch diameter and smaller) on non-safety related dead weight supports in Category I areas which we deemed reportable under the provisions of 10CFR50.55(e). Our last interim report was logged TXX-6970, dated November 24, 1987.

We are continuing our evaluation of the corrective actions for Unit 2 and will submit our next report no later than September 20, 1988.

Very truly yours,

W. G. Council

W. G. Council

By: *J. S. Marshall*

J. S. Marshall
Supervisor,
Docket Licensing

DAR/grr

c - Mr. R. D. Martin, Region IV
Resident Inspectors, CPSES (3)

8803080221 880301
PDR ADOCK 05000445
S DCD

FE27
1/0