

Enclosure to
NRC-87-0272
Page 4

PROPOSED PAGE CHANGE

BB01220258 030115
PDR ADDCK 05000341
P PDR

EMERGENCY CORE COOLING SYSTEMS

SURVEILLANCE REQUIREMENTS

4.5.2.1 At least the above required ECCS shall be demonstrated OPERABLE per Surveillance Requirement 4.5.1,

4.5.2.2 The core spray system shall be determined OPERABLE at least once per 12 hours by verifying the condensate storage tank required volume when the condensate storage tank is required to be OPERABLE per Specification 3.5.2.a.2.b.

with the exception that, for the LPCI system, the cross-tie valve may be closed to isolate a subsystem if the OPERABLE subsystem is made capable of injection to the reactor vessel.