

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

8 9 G A E I H 2 2 0 0 0 0 0 0 0 0 0 0 3 4 1 1 1 1 1 1 4 5 6 7 CAT 58

LICENSEE CODE LICENSE NUMBER LICENSE TYPE

17  
1  
8

REPORT SOURCE

60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80

DOCKET NUMBER

EVENT DATE

REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

2] During a steady state of operation, while performing procedure HNP-2-3410 (RCIC  
3] Steam Line Flow F.T. & C.), 2E51-N017 was found to trip at -116 inches of water  
4] for the low setpoint and 111.9 inches of water at the high setpoint. The limits  
5] for these setpoints are  $\geq -111$  inches of water and  $\leq 111$  inches of water per  
6] Technical Specification Table 3. 3.2-2. There were no effects to public health or  
7] safe plant operation as 2E51-N018 was operable at the time.

SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE				COMP. SUBCODE		VALVE SUBCODE					
C	E	X		Z		I	N	S	T	R	U	S	Z				
EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.									
7	8	0	7	9	0	3	L		0								
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPRD-4 FORMS-8		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER	
E	Z	Z	Z		0	0	0	0	0	N	N	N	B	0	8	0	

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

0 The cause has been attributed to instrument drift. 2E51-N017 was recalibrated per

1 procedure HNP-2-5202 and procedure HNP-2-3410 was completed satisfactorily. The

2 instrument is a Barton Model 288A switch.

FACILITY STATUS								% POWER						OTHER STATUS							METHOD OF DISCOVERY				DISCOVERY DESCRIPTION								
B								066						NA							B				Surveillance Testing								
ACTIVITY CONTENT RELEASED OR RELEASE										AMOUNT OF ACTIVITY										LOCATION OF RELEASE													
Z										NA																							
PERSONNEL EXPOSURES NUMBER										TYPE										DESCRIPTION													
000										Z										NA													
PERSONNEL INJURIES NUMBER										DESCRIPTION																							
000										NA																							
LOSS OF OR DAMAGE TO FACILITY TYPE										DESCRIPTION																							
Z										NA																							
PUBLICITY ISSUED										DESCRIPTION																							
N										NA																							

NAME OF PREPARER R. T. Nix  
Maintenance Superintendent

PHONE: (912) 367-7781

7812270317

600