

ENCLOSURE 5

BRUNSWICK STEAM ELECTRIC PLANT, UNITS 1 AND 2
NRC DOCKETS 50-325 & 50-324
OPERATING LICENSES DPR-71 & DPR-62
REQUEST FOR LICENSE AMENDMENT

UNIT 1 TECHNICAL SPECIFICATION PAGES

ELECTRICAL POWER SYSTEMSLIMITING CONDITION FOR OPERATION (Continued)ACTION (Continued)

2. Restore at least one of the inoperable offsite sources to OPERABLE status within 24 hours or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours;
 3. With one offsite source restored, demonstrate the OPERABILITY of the remaining A.C. power sources as required by ACTION a; restore two offsite circuits to OPERABLE status within 72 hours from time of initial loss or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.
- e. With two of the above required diesel generators inoperable:
1. Demonstrate the OPERABILITY of the remaining A.C. power sources by performing Surveillance Requirements 4.8.1.1.1.a, 4.8.1.1.2.a.4, and 4.8.1.1.2.a.5 within 2 hours and at least once per 12 hours thereafter;
 2. Restore at least three diesel generators to OPERABLE status within 2 hours or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours;
 3. With one diesel generator restored, demonstrate the OPERABILITY of the remaining A.C. power sources as required by ACTION b; restore at least 4 diesel generators to OPERABLE status within 7 days from time of initial loss or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.

SURVEILLANCE REQUIREMENTS

4.8.1.1.1 Each of the above required independent circuits between the offsite transmission network and the onsite Class 1E distribution system shall be determined OPERABLE at least once per 7 days by verifying correct breaker alignments and indicated power availability.

ENCLOSURE 6

BRUNSWICK STEAM ELECTRIC PLANT, UNITS 1 AND 2
NRC DOCKETS 50-325 & 50-324
OPERATING LICENSES DPR-71 & DPR-62
REQUEST FOR LICENSE AMENDMENT

UNIT 2 TECHNICAL SPECIFICATION PAGES

ELECTRICAL POWER SYSTEMSLIMITING CONDITION FOR OPERATION (Continued)ACTION (Continued)

2. Restore at least one of the inoperable offsite sources to OPERABLE status within 24 hours or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours;
 3. With one offsite source restored, demonstrate the OPERABILITY of the remaining A.C. power sources as required by ACTION a; restore two offsite circuits to OPERABLE status within 72 hours from time of initial loss or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.
- e. With two of the above required diesel generators inoperable:
1. Demonstrate the OPERABILITY of the remaining A.C. power sources by performing Surveillance Requirements 4.8.1.1.1.a, 4.8.1.1.2.a.4, and 4.8.1.1.2.a.5 within 2 hours and at least once per 12 hours thereafter;
 2. Restore at least three diesel generators to OPERABLE status within 2 hours or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours;
 3. With one diesel generator restored, demonstrate the OPERABILITY of the remaining A.C. power sources as required by ACTION b; restore at least 4 diesel generators to OPERABLE status within 7 days from time of initial loss or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.

SURVEILLANCE REQUIREMENTS

4.8.1.1.1 Each of the above required independent circuits between the offsite transmission network and the onsite Class 1E distribution system shall be determined OPERABLE at least once per 7 days by verifying correct breaker alignments and indicated power availability.