(7 77)

LICENSEE EVENT REPORT

CONTROL BLOCK (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | N C B E P 1 (2) | 0 0 - 0 0 0 0 0 - 0 0 (3) | 4 1 1 1 1 (4) | (5)

7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

CON'T

0 1 | REPORT SOURCE L (6) | 0 5 0 - 0 3 2 5 (7) | 1 2 2 4 7 9 (8) | 0 1 1 7 8 0 (9)

7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 During normal plant operation, the control operator noticed that the containment

0 3 atmospheric monitor CAC-AR-1263 had failed downscale.

0 4

0 5

0 6

0 7

0 8 Technical Specifications 3.3.5.3, 6.9.1.9b

7 8 9 80

SYSTEM CODE | CAUSE CODE | CAUSE SUBCODE | COMPONENT CODE | COMP SUBCODE | VALVE SUBCODE

0 9 | S D (11) | E (12) | A (13) | I N S T R U (14) | P (15) | Z (16)

7 8 9 10 11 12 13 18 19 20

(17) LER RO REPORT NUMBER | EVENT YEAR | SEQUENTIAL REPORT NO. | OCCURRENCE CODE | REPORT TYPE | REVISION NO

7 9 | — | 1 1 5 | / | 0 3 | L | — | 0

21 22 23 24 26 27 28 29 30 31 32

ACTION TAKEN | FUTURE ACTION | EFFECT ON PLANT | SHUTDOWN METHOD | HOURS (22) | ATTACHMENT SUBMITTED | NPRDS FORM SUB | PRIME COMP SUPPLIER | COMPONENT MANUFACTURER

B (18) | G (19) | Z (20) | Z (21) | 0 0 0 0 | N (23) | Y (24) | A (25) | B 1 3 5

33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The input power cable was found to have a bare section which was coming in contact

1 1 with the case, thus grounding the power supply. The cable was repaired and the

1 2 recorder returned to service. Maintenance Instruction MI 10-1.A will be revised

1 3 to include an inspection of the cable assembly.

1 4

7 8 9 80

FACILITY STATUS | % POWER | OTHER STATUS (30) | METHOD OF DISCOVERY | DISCOVERY DESCRIPTION (32)

1 5 | E (28) | 0 9 3 (29) | N/A | A (31) | Operator Surveillance

7 8 9 10 12 13 44 45 46 80

ACTIVITY RELEASED | CONTENT OF RELEASE | AMOUNT OF ACTIVITY (35) | LOCATION OF RELEASE (36)

1 6 | Z (33) | Z (34) | N/A | N/A

7 8 9 10 11 44 45 80

PERSONNEL EXPOSURES

NUMBER | TYPE | DESCRIPTION (39)

1 7 | 0 0 0 (37) | Z (38) | N/A

7 8 9 11 12 13 80

PERSONNEL INJURIES

NUMBER | DESCRIPTION (41)

1 8 | 0 0 0 (40) | N/A

7 8 9 11 12 80

LOSS OF OR DAMAGE TO FACILITY

TYPE | DESCRIPTION (43)

1 9 | Z (42) | N/A

7 8 9 10 80

90030068

PUBLICITY

ISSUED | DESCRIPTION (45)

2 0 | N (44) | N/A

7 8 9 10 68 69 80

NRC USE ONLY

NAME OF PREPARER A. C. Tollison, Jr. PHONE 919-457-9521

8001220 475