



SMUD

SACRAMENTO MUNICIPAL UTILITY DISTRICT ☐ P. O. Box 15830, Sacramento CA 95852-1830, (916) 452-3211
AN ELECTRIC SYSTEM SERVING THE HEART OF CALIFORNIA

MAR 09 1988

GCA 88-163

U. S. Nuclear Regulatory Commission
Attn: J. B. Martin, Regional Administrator
Region V
1450 Maria Lane, Suite 210
Walnut Creek, CA 94596

Docket No. 50-312
Rancho Seco Nuclear Generating Station
License No. DPR-54
REQUEST FOR EXTENSION FOR THE TDI DIESEL GENERATOR 24-HOUR
SURVEILLANCE RUN

Dear Mr. Martin:

In your letter of February 26, 1988, you granted an enforcement discretion from the requirements of Technical Specification 4.6.3.C.6 that would expire on March 10, 1988. Specifically, the relief concerned the completion of 24-hour surveillance runs on the TDI diesel generators. During the performance of the 24-hour surveillance run on the "B" train, a fatigue failure of a weld occurred resulting in schedule delays for the remainder of the 24-hour surveillance runs. We expect to complete the 24-hour surveillance run for both trains beyond the date specified in your letter; therefore, we request that the date for completion of the 24-hour surveillance runs be extended to March 20, 1988, to provide time for completion of the runs, contingencies and results review. The basis for the original request has not changed and the testing in all likelihood will be completed prior to March 12, 1988.

We have discussed this matter with members of your staff and are prepared to meet with you if requested.

8803220032 880309
PDR ADCK 05000312
DCD

JE01


J. B. Martin

-2-

GCA 88-163

Please contact me if you have any questions. Members of your staff requiring additional information or clarification may contact Steve Crunk at (209) 333-2935, extension 4913.

Sincerely,



G. Carl Andognini
Chief Executive Officer, Nuclear

cc: A. D'Angelo, NRC, Rancho Seco
G. Kalman, NRC, Rockville (2)
F. Miraglia, NRC, Rockville
D. Crutchfield, NRC, Rockville