

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

5N 157B Lookout Place

MAR 16 1988

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D.C. 20555

Gentlemen:

In the Matter of )  
Tennessee Valley Authority )

Docket Nos. 50-327  
50-328

SEQUOYAH NUCLEAR PLANT (SQN) - REVISION TO RESPONSE TO NRC INSPECTION REPORT  
NOS. 50-327/87-50 AND 50-328/87-50

In response to a verbal request from the SQN resident inspector, I am submitting this revision to my November 4, 1987 response to NRC's concerns relative to violations 50-327/84-24-01 and -02.

This submittal addresses only example e of violation 50-327/84-24-01 and reflects current procedural requirements regarding hold orders and caution orders.


Administrative Instruction (AI) 3, revision 40, does not allow the use of caution orders for personnel safety. Section 3.1.5.3 states that, "A caution order will not be used as a clearance boundary or in-plant for protection and safety of personnel." Under plant emergency conditions, the shift supervisor may authorize the removal of hold notices and operate equipment under his control to place the plant in a safe condition. The shift supervisor returning equipment to service under these conditions is responsible for the safety of plant personnel.

AI-3, section 5.3.1.2, requires that, under normal conditions, no work begin on the subject equipment until the clearance has been issued to the person responsible for the work. Additionally, clearances may only be issued to properly authorized employees whose names appear on the official clearance list. The shift supervisor may hold a clearance for emergency maintenance purposes or for manufacturers' representatives or TVA personnel on special assignment.

If you have any questions, please telephone M. R. Harding at (615) 870-6422.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

  
R. Gridley, Director  
Nuclear Licensing and  
Regulatory Affairs

cc: See page 2

8803220088 880316  
PDR ADOCK 05000327  
Q DCD

An Equal Opportunity Employer

1E01  
1/0

MAR 16 1988

U.S. Nuclear Regulatory Commission

cc: Mr. K. P. Barr, Acting Assistant Director  
for Inspection Programs  
TVA Projects Division  
U.S. Nuclear Regulatory Commission  
Region II  
101 Marietta Street, NW, Suite 2900  
Atlanta, Georgia 30323

Mr. G. G. Zech, Assistant Director  
for Projects  
TVA Projects Division  
U.S. Nuclear Regulatory Commission  
One White Flint, North  
11555 Rockville Pike  
Rockville, Maryland 20852

Sequoyah Resident Inspector  
Sequoyah Nuclear Plant  
2600 Igou Ferry Road  
Soddy Daisy, Tennessee 37379