



Northeast  
Utilities System

Millstone Offices • Rope Ferry Rd., Waterford, CT

P.O. Box 128  
Waterford, CT 06385-0128  
(860) 447-1791

**MAY 27 1997**

Docket No. 50-245

B16436

Re: 10CFR50.73(a)(2)(i)

U.S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555

This letter forwards Licensee Event Report (LER) 97-025-00, documenting an event that occurred at Millstone Nuclear Power Station, Unit No. 1 on April 24, 1997. This LER is submitted pursuant to 10CFR50.73(a)(2)(ii).

The following are Northeast Nuclear Energy Company's (NNECO's) commitments made within this letter. All other statements made within this letter are for information only.

- B16436-1 NNECO commits to submit to the NRC for approval, a revision to Technical Specification 3.6.G and Technical Specification Surveillance Requirement 4.6.G prior to startup for operating cycle 16. The new specifications and requirements, relating to jet pump integrity and operability, will be similar to those established by the industry in the Standard Technical Specifications, NUREG-1433.
- B16436-2 NNECO commits that a review of the Technical Specifications requirements will be performed to ensure procedures exist to adequately implement all requirements in the Technical Specifications prior to startup for operating cycle 16.

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY

For: P. D. Hinnenkamp  
Director, Unit Operations

By: W. G. Noll  
Manager, Operations

IE221

9705290095 970527  
PDR ADOCK 05000245  
S PDR



Attachment: LER 97-025-00

cc: Dr. W. D. Travers, Director, Special Projects  
H. J. Miller, Region I Administrator  
S. Dembek, NRC Project Manager, Millstone Unit No. 1  
T. A. Easlick, Senior Resident Inspector, Millstone Unit No. 1