

DL&R:FWK
Docket No. 50-29

APR 25 1961

Yankee Atomic Electric Company
441 Stuart Street
Boston 16, Massachusetts

Attention: Mr. Roger J. Coe
Vice President

THIS DOCUMENT CONTAINS
POOR QUALITY PAGES

Gentlemen:

This is in reply to your request dated February 10, 1961, for AEC authorization to make Proposed Change No. 1 in your facility pursuant to paragraph 3.A.2.4. of License No. DPR-3, as amended.

We have reviewed the proposed modifications to the facility and have found that the addition of a motor operating mechanism to valve No. 26, the demineralizer water fill line valve, and the installation of related switches and indicating lights on the main control board should contribute to safer operation of the facility and does not present significant hazards considerations not described or implicit in the license application, as amended to January 12, 1961, and there is reasonable assurance that the health and safety of the public will not be endangered by operation of the facility as proposed. A copy of our analysis of the operation of the facility with the modifications described is attached hereto.

In view of the foregoing, authorization is hereby granted to Yankee Atomic Electric Company to install a motor operating mechanism to valve No. 26, the demineralizer water fill line valve, and to install related switches and indicating lights on the main control board in accordance with Yankee's Proposed Change No. 1, dated February 10, 1961.

Doc. Rm. *P.A. Thomas*
Formal *J. G. Chas*
Suppl. *M. B. Bles*
LB & L&R
FWKaras

Sincerely yours,

R. Lowenstein, Acting

Director
Division of Licensing and Regulation *NY 154-61*

OFFICE	DL&R	DL&R	DL&R	R&PRSB	OGC	Director
ATTACHMENT	<i>FWK</i>	<i>FWK</i>	<i>FWK</i>	<i>FWK</i>	<i>FWK</i>	<i>FWK</i>
SURNAME	FWKaras/vj	FWKaras/vj	LJohnson		<i>Kent</i>	<i>RJL</i>
DATE	4/14/61	4/14		<i>gyl</i>	4/21/61	4-25-61

8011080 833