



UNITED STATES
ATOMIC ENERGY COMMISSION
WASHINGTON 25, D.C.

MAR 26 1962

Docket No. 50-29

Change No. 16

Yankee Atomic Electric Company
441 Stuart Street
Boston 16, Massachusetts

Attention: Mr. Roger J. Coe
Vice President

Gentlemen:

Distribution

C. R. Boer	R. Hazard
R. Lowenstein	Doc. Room
P. L. Kirk	Formal
T. G. Case	Suppl.
R. Shaper	LB-L&R readings
P. Travelstead	
P. A. Morris-2	
E. E. Hall	
E. C. Clark	
T. Tremel	
H. Steele	

This refers to your request dated January 18, 1962 for AEC authorization to make Proposed Change No. 16 in your facility pursuant to paragraph 3.A of License No. DPR-3, as amended.

We have reviewed the proposed change in technical specifications and have found that installation of an instrumentation connection in the high side line to the wide range pressurized level differential pressure cell together with valving and connecting piping as proposed does not present significant hazards considerations not described or implicit in the license application as amended to June 23, 1961, and that there is reasonable assurance that the health and safety of the public will not be endangered by operation of the facility as proposed. A copy of our related hazards analysis is enclosed.

In view of the foregoing, Yankee Atomic Electric Company is hereby authorized under License No. DPR-3 to install an instrumentation connection in the high side line to the wide range pressurizer level differential pressure cell together with valving and connecting piping in accordance with Yankee's request dated January 18, 1962 entitled Proposed Change No. 16.

Sincerely yours,

Original Signed by R. L. Hill

Director
Division of Licensing and
Regulation

Enclosure:
Hazards Analysis

THIS DOCUMENT CONTAINS
POOR QUALITY PAGES

DL&R
C. Edwards/dk
3/20/62

DL&R
mcy
MGaske

DL&R
RHE
3/21/62

OGC
W. Stewart
H&S
3/22/62

DL&R
T.M.C.
Director
3-26-62

8011060 836