

  
Docket No, 50-29

DRoss  
TBAbernathy  
JRBuchanan

OCT 7 1976

DISTRIBUTION  
Docket  
NRC PDR  
Local PDR  
ORB#1 Reading  
VStello  
KRGoller/TJCarter  
SMSheppard  
ABurger  
OELD  
OI&E(5)  
BJones(4)  
BScharf(15)  
JMcGough  
DEisenhut  
ACRS(16)  
CMiles(OPA)

Yankee Atomic Electric Company  
ATTN: Mr. Robert H. Groce  
Licensing Engineer  
20 Turnpike Road  
Westboro, Massachusetts 01581

Gentlemen:

The Commission has issued the enclosed Amendment No. 25 to Facility License No. DPR-3 for the Yankee Nuclear Power Station (Yankee-Rowe). The amendment consists of changes to the Technical Specifications and is in response to your application dated May 11, 1976, and supplements dated May 11, 17, 19, 1976, and June 16, 1976.

This amendment changes the requirement in the Technical Specifications relating to the ECCS accumulator Pressure, to reflect actual accumulator flow (based on acceptable plant tests) in the ECCS performance analysis for Core XII which we have previously found to be acceptable and in compliance with 10 CFR §50.46.

Copies of the Safety Evaluations dated May 19, 1976 and the Federal Register Notice are also enclosed.

This amendment does not permit the Yankee-Rowe reactor to operate outside the limit of the NRC Order for Modification of License dated August 27, 1976, and does not affect the requirements of that Order.

Sincerely,

Original signed by

A. Schwencer, Chief  
Operating Reactors Branch #1  
Division of Operating Reactors

Enclosures:

1. Amendment No. 25 to DPR-3
2. Safety Evaluations dtd 5/19/76  
and 10/7/76
3. Federal Register Notice

FOR PREVIOUS CONCURRENCES SEE ATTACHED YELLOW.

8011070/3/

