

Docket

UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

MAR 14 1975

Docket No. 50-29

Yankee Atomic Electric Company
ATTN: Mr. G. Carl Andognini, Assistant
to the Vice President
20 Turnpike Road
Westboro, Massachusetts 01581

Gentlemen:

Although your emergency core cooling systems generally satisfy our requirements with regard to long-term cooling, the system configurations have not been specifically evaluated to show that significant changes in chemical concentrations would not occur during the long term after a loss-of-coolant accident (LOCA) and these potential changes have not been specifically addressed by appropriate operating procedures. Accordingly, you should review your system capabilities and operating procedures to assure that boron precipitation would not compromise long-term core cooling capability following a LOCA. This review should consider all aspects of your design, including component qualification in the LOCA environment in addition to a detailed review of operating procedures. You should examine the vulnerability of your design to single failures that would result in any significant boron precipitation.

You should submit this evaluation and associated operating procedures within 30 days of receipt of this letter. These procedures should be promptly effected to assure that boron precipitation would not interfere with the ability of your facility to conform to Criterion (5) of 10 CFR 50.46(b). We will inform you as to the acceptability of your evaluation and associated operating procedures.

While solute concentrations may be subject to control through operating procedures, equipment modifications may be required or desirable to simplify such procedures. Your submittal should include a plan for completing such modifications within six months of the date of this letter.

THIS DOCUMENT CONTAINS
POOR QUALITY PAGES

8011170

398

P

MAR 14 1975

This request for generic information was approved by GAO under a blanket clearance number B-180225 (R0072); this clearance expires July 31, 1975.

Sincerely,

Original signed by
R. A. Purple

Robert A. Purple, Chief
Operating Reactors Branch #1
Division of Reactor Licensing

cc: See next page

DISTRIBUTION

Docket File
NRC PDR
Local PDR
ORB#1 Reading
KRGoller
TJCarter
SVarga
RAPurple
ABurger
SMSheppard
OELD
OI&E (3)
ACRS (14)

OFFICE	RL:ORB#1	RL:ORB#1			ECCS	12
SURNAME	ABurger:dc	RAPurple			10	
DATE	3/13/75	3/14/75				

MAR 14 1975

cc: Mr. Donald G. Allen, President
Yankee Atomic Electric Company
20 Turnpike Road
Westboro, Massachusetts 01581