

Docket No. 50-29

Yankee Atomic Electric Company  
ATTN: Mr. Robert H. Groce  
Licensing Engineer  
20 Turnpike Road  
Westboro, Massachusetts 01581

MAY 02 1978

DISTRIBUTION

Docket  
NRC PDR  
Local PDR  
ORB #2 Reading  
VStello  
DEisenhut  
OELD  
OI&E (3)  
DLZiemann  
ABurger  
HSmith  
BGrimes  
TBAbernathy  
JRBuchanan ACRS (16)

Gentlemen:

On March 29, 1977, we requested that you evaluate the alarm circuitry and diesel generator control circuitry for the diesel generators at Yankee-Rowe. The stated purpose of the evaluation was to determine how each condition that renders a diesel generator unable to respond to an automatic emergency start signal is alarmed in the control room.

You responded by letters dated May 10, 1977, and April 13, 1978. In addition to providing the results of your evaluation, you proposed to implement during the December 1978 refueling outage specific modifications to improve the diesel generator annunciator alarm provisions.

Based on our review of your responses, we have concluded that your evaluation of the alarm systems, with the modifications to be implemented as proposed by you, adequately address the concerns expressed in our letter to you dated March 29, 1977, and are acceptable.

Sincerely,

Original signed by  
Dennis L. Ziemann

Dennis L. Ziemann, Chief  
Operating Reactors Branch #2  
Division of Operating Reactors

cc: See next page

THIS DOCUMENT CONTAINS  
POOR QUALITY PAGES

8011170 940

283

P

OFFICE	DOR:ORB #2	DOR:ORB #2				
SURNAME	ABurger:ah	DLZiemann				
DATE	5/2/78	5/1/78				

Yankee Atomic Electric Company

- 2 -

MAY 02 1978

cc

Mr. Donald C. Allen, President  
Yankee Atomic Electric Company  
20 Turnpike Road  
Westboro, Massachusetts 01581

Greenfield Community College  
1 College Drive  
Greenfield, Massachusetts 01301