



UNITED STATES
ATOMIC ENERGY COMMISSION
WASHINGTON, D.C. 20545

Distribution
H. J. McAlduff, OROO
E. G. Case
H. Shapar
L. Kornblith - 2
P. Travelstead
H. Steele
G. Page
R. Huard
Document Room
Formal
Supplemental
DL&R Reading
R&PRSB Reading
N. D. Mason
Change No. 32

Docket No. 50-29

Yankee Atomic Electric Company
441 Stuart Street
Boston 16, Massachusetts

Attention: Mr. Roger J. Coe
Vice President

Gentlemen:

This refers to your request dated March 19, 1963, and supplement thereto dated August 23, 1963, for AEC authorization of Proposed Change No. 32 in the Technical Specifications of Facility License No. DPR-3 pursuant to the provisions of Section 50.59, 10 CFR 50. The Proposed Change would authorize the installation of a vent line which would provide a means of establishing a continuous controlled flow of gas from the vapor phase portion of the reactor pressurizer to the low pressure surge tank.

We have reviewed the Proposed Change and have found that it does not present significant hazards considerations not described or implicit in the hazards summary report, and that there is reasonable assurance that the health and safety of the public will not be endangered. A copy of our related hazards analysis is enclosed. In view of the foregoing, Proposed Change No. 32 and supplement thereto are hereby authorized pursuant to Section 50.59, 10 CFR 50.

Sincerely yours,

Original signed
by R. L. Mason

Director
Division of Licensing & Regulation

Enclosure:
Hazards Analysis

R&PRSB:DL&R
NDMason
9/6/63

R&PRSB:DL&R
MGaske
9/6/63

R&PRSB:DL&R
RMBryan
9/6/63

OGX
FL:DL&R
ECCase
9/6/63 9/8/63

DL&R
Director
9/7/63

8011190 776

Change No. 32

THIS DOCUMENT CONTAINS
POOR QUALITY PAGES

P