

March 24, 1988

Docket No. 50-458

Mr. James C. Deddens
Senior Vice President, (RBNG)
Gulf States Utilities
P. O. Box 220
St. Francisville, LA 70775
ATTN: Nuclear Licensing

Dear Mr. Deddens:

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION - GENERIC
LETTER 83-28, ITEM 2.1 (PART 1)

Gulf States Utilities responded to Item 2.1 (Part 1), "Equipment Classification Program (Programs for Reactor Trip System Components)" of Generic Letter 83-28, by letters dated August 3, 1984 and May 20, 1985. Our review of these submittals discloses the need for additional information as described in the enclosure.

Please provide your response to the enclosure within 45 days of the receipt of this letter.

The reporting and/or recordkeeping requirements contained in this letter affect fewer than ten respondents; therefore, OMB clearance is not required under P.L. 96-511.

Sincerely,

15

Walter A. Paulson, Project Manager
Project Directorate - IV
Division of Reactor Projects - III,
IV, V and Special Projects

Enclosure:
As stated

cc w/enclosure:
See next page

DISTRIBUTION

Docket File
DR4A/J. Collins
OGC-Rockville
PD4 Plant File

NRC PDR
J. Calvo
E. Jordan

Local PDR
P. Noonan
J. Partlow

PD4 Reading
W. Paulson
ACRS (10)

PD4/LA *pm*
PNoonan
03/23/88

mc
PD4/PM *wp*
WPaulson:sr
03/24/88

PD4/D *mc*
JCalvo
03/24/88

8803300279 880324
PDR ADDOCK 05000458
P PDR

March 24, 1988

Docket No. 50-458

Mr. James C. Deddens
Senior Vice President, (RBNG)
Gulf States Utilities
P. O. Box 220
St. Francisville, LA 70775
ATTN: Nuclear Licensing

Dear Mr. Deddens:

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION - GENERIC
LETTER 83-28, ITEM 2.1 (PART 1)

Gulf States Utilities responded to Item 2.1 (Part 1), "Equipment Classification Program (Programs for Reactor Trip System Components)" of Generic Letter 83-28, by letters dated August 3, 1984 and May 20, 1985. Our review of these submittals discloses the need for additional information as described in the enclosure.

Please provide your response to the enclosure within 45 days of the receipt of this letter.

The reporting and/or recordkeeping requirements contained in this letter affect fewer than ten respondents; therefore, OMB clearance is not required under P.L. 96-511.

Sincerely,

(s)

Walter A. Paulson, Project Manager
Project Directorate - IV
Division of Reactor Projects - III,
IV, V and Special Projects

Enclosure:
As stated

cc w/enclosure:
See next page

DISTRIBUTION

Docket File
DR4A/J. Collins
OGC-Rockville
PD4 Plant File

NRC PDR
J. Calvo
E. Jordan

Local PDR
P. Noonan
J. Partlow

PD4 Reading
W. Paulson
ACRS (10)

PD4/LA *JP*
PNoonan
03/23/88

WAP
PD4/PM *WP*
WPaulson:sr
03/24/88

PD4/D *WAP*
JCalvo
03/24/88



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555
March 24, 1988

Docket No. 50-458

Mr. James C. Deddens
Senior Vice President, (RBNG)
Gulf States Utilities
P. O. Box 220
St. Francisville, LA 70775
ATTN: Nuclear Licensing

Dear Mr. Deddens:

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION - GENERIC
LETTER 83-28, ITEM 2.1 (PART 1)

Gulf States Utilities responded to Item 2.1 (Part 1), "Equipment Classification Program (Programs for Reactor Trip System Components)" of Generic Letter 83-28, by letters dated August 3, 1984 and May 20, 1985. Our review of these submittals discloses the need for additional information as described in the enclosure.

Please provide your response to the enclosure within 45 days of the receipt of this letter.

The reporting and/or recordkeeping requirements contained in this letter affect fewer than ten respondents; therefore, OMB clearance is not required under P.L. 96-511.

Sincerely,

A handwritten signature in cursive script, reading "Walter A. Paulson".

Walter A. Paulson, Project Manager
Project Directorate - IV
Division of Reactor Projects - III,
IV, V and Special Projects

Enclosure:
As stated

cc w/enclosure:
See next page

Mr. James C. Deddens
Gulf States Utilities Company

River Bend Nuclear Plant

cc:
Troy B. Conner, Jr., Esq.
Conner and Wetterhahn
1747 Pennsylvania Avenue, NW
Washington, D.C. 20006

Mr. J. E. Booker
Manager-River Bend Oversight
P. O. Box 2951
Beaumont, TX 77704

Director - Nuclear Licensing
Gulf States Utilities Company
P. O. Box 220
St. Francisville, LA 70775

Mr. William H. Spell, Administrator
Nuclear Energy Division
Office of Environmental Affairs
P. O. Box 14690
Baton Rouge, Louisiana 70898

Richard M. Troy, Jr., Esq.
Assistant Attorney General in Charge
State of Louisiana Department of Justice
234 Loyola Avenue
New Orleans, Louisiana 70112

Mr. J. David McNeill, III
William G. Davis, Esq.
Department of Justice
Attorney General's Office
7434 Perkins Road
Baton Rouge, Louisiana 70808

Resident Inspector
P. O. Box 1051
St. Francisville, Louisiana 70775

H. Anne Plettinger
3456 Villa Rose Drive
Baton Rouge, Louisiana 70806

Gretchen R. Rothschild-Reinike
Louisianians for Safe Energy, Inc.
2108 Broadway Street
New Orleans, Louisiana 70118-5462

President of West Feliciana
Police Jury
P. O. Box 1921
St. Francisville, Louisiana 70775

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
Office of Executive Director
for Operations
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011

Mr. Frank J. Uddo
Uddo & Porter
6305 Elysian Fields Avenue
Suite 400
New Orleans, Louisiana 70122

Philip G. Harris
Cajun Electric Power Coop. Inc.
10719 Airline Highway
P. O. Box 15540
Baton Rouge, LA 70895

RIVER BEND STATION
DOCKET NO. 50-458
REQUEST FOR ADDITIONAL INFORMATION
FOR GENERIC LETTER 83-28, ITEM 2.1 (PART 1)

INTRODUCTION:

We have reviewed the response to Generic Letter 83-28, Item 2.1 (Part 1), dated August 3, 1984 and May 20, 1985 provided by Gulf States Utilities Company, the licensee for the River Bend Station, and find them acceptable with the following exception. The licensee is requested to provide additional information for these items as described below.

Evaluation and Specific Information Request:

Evaluation:

The licensee's submittal of August 3, 1984 described a program that was being developed to meet the requirements of this item. Their next submittal dated May 20, 1985 stated that they had initiated a program to ensure that reactor trip components are identified and labeled as safety-related on relevant plant documents. The estimated completion date was stated to be August 15, 1985.

Conclusion:

Based on the licensee's submittals, we are unable to conclude that the licensee has completed and implemented a program of equipment classification that meets the requirements of this item because we have received no further information from the licensee confirming completion and implementation of a program. The licensee should identify the program to be used and confirm its completion and implementation.