



**Northeast
Nuclear Energy**

Rope Ferry Rd. (Route 156), Waterford, CT 06385

Millstone Nuclear Power Station
Northeast Nuclear Energy Company
P.O. Box 128
Waterford, CT 06385-0128
(860) 447-1791
Fax (860) 444-4277

The Northeast Utilities System

JUN 10 1997

Docket No. 50-245
B16527

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555

**Millstone Nuclear Power Station, Unit No. 1
Facility Operating License No. DPR-21
Monthly Operating Report**

In accordance with the reporting requirements of Technical Specification Section 6.9.1.6 for Millstone Unit No. 1, enclosed is the monthly operating report for the month of May 1997.

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY




Paul Hinnenkamp
Director - Unit Operations
Millstone Unit No. 1

Attachments (1)

cc: Dr. W. D. Travers, Director, Special Projects
H. J. Miller, Region I Administrator
S. Dembek, NRC Project Manager, Millstone Unit No. 1
T. A. Easlick, Senior Resident Inspector, Millstone Unit No. 1

9706180295 970531
PDR ADOCK 05000245
R PDR



Docket No. 50-245
B16527

Attachment 1

Millstone Unit No. 1

Facility Operating License No. DPR-21

Monthly Operating Report - May

June 1997

OPERATING DATA REPORT

UNIT NAME Millstone Unit 1
DATE 6/4/97
COMPLETED BY G. Newburgh
TELEPHONE (860)444-5730

OPERATING STATUS

1. Docket Number 50-245
2. Reporting Period May 1997
3. Utility Contact G. Newburgh
4. Licensed Thermal Power (MWt): 2011
5. Nameplate Rating (Gross MWe): 662
6. Design Electrical Rating (Net MWe): 660
7. Maximum Dependable Capacity (Gross MWe): 670
8. Maximum Dependable Capacity (Net MWe): 641
9. If Changes Occur in Capacity Ratings (Items Number 4 Through 8) Since Last Report, Give Reasons:
N/A

Notes:

10. Power Level To Which Restricted, If any (Net MWe): 0
11. Reasons For Restrictions, If Any: Regulatory Restriction (10CFR50.54f)

	This Month	Yr.-To-Date	Cumulative
12. Hours In Reporting Period	744.0	3623.0	231623.0
13. Number Of Hours Reactor Was Critical	0.0	0.0	170529.9
14. Reactor Reserve Shutdown Hours	0.0	0.0	3283.3
15. Hours Generator On-Line	0.0	0.0	166560.7
16. Unit Reserve Shutdown Hours	0.0	0.0	93.7
17. Gross Thermal Energy Generated (MWH)	0.0	0.0	314372827.0
18. Gross Electrical Energy Generated (MWH)	0.0	0.0	105938737.0
19. Net Electrical Energy Generated (MWH)	-2022.0	-10919.0	101032630.0
20. Unit Service Factor	0.0	0.0	71.9
21. Unit Availability Factor	0.0	0.0	72.0
22. Unit Capacity Factor (Using MDC Net)	-0.4	-0.5	66.7
23. Unit Capacity Factor (Using DER Net)	-0.4	-0.5	66.1
24. Unit Forced Outage Rate	100.0	100.0	17.3
25. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each): Shutdown at time of this report			

26. If Unit Shutdown At End Of Report Period, Estimated Date of Startup: To be determined
27. Units In Test Status (Prior to Commercial Operation):

INITIAL CRITICALITY
INITIAL ELECTRICITY
COMMERCIAL OPERATION

Forecast	Actual
N/A	N/A
N/A	N/A
N/A	N/A

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-245

UNIT NAME Millstone Unit 1COMPLETED BY G. NewburghTELEPHONE (860)-444-5730

REPORT MONTH: May, 1997

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	License Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
95-10Q	951213	F	744	D	4		N/A		10CFR50.54f

¹ F: Forced
S: Scheduled

² Reason
A - Equipment Failure (Explain)
B - Maintenance or Test
C - Refueling
D - Regulatory Restriction
E - Operator Training & License Examination
F - Administrative
G - Operational Error (Explain)
H - Other (Explain)

³ Method
1 - Manual
2 - Manual Scram
3 - Automatic Scram
4 - Continued from Previous Month
5 - Power Reduction (Duration = 0)
6 - Other (Explain)

⁴ IEEE Standard 805-1984,
"Recommended Practices
for System Identification in
Nuclear Power Plants and
Related Facilities"

⁵ IEEE Standard 803A-1983,
"Recommended Practices
for Unique identification in
Power Plants and Related
Facilities - Component
Function Identifiers"

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO: 50-245

UNIT: Millstone Unit 1

DATE: 6/4/97

COMPLETED BY: G. Newburgh

TELEPHONE: (860) 444-5730

MONTH: May, 1997

DAY AVG. DAILY POWER LEVEL
(MWe-Net)

1	<u>0</u>
2	<u>0</u>
3	<u>0</u>
4	<u>0</u>
5	<u>0</u>
6	<u>0</u>
7	<u>0</u>
8	<u>0</u>
9	<u>0</u>
10	<u>0</u>
11	<u>0</u>
12	<u>0</u>
13	<u>0</u>
14	<u>0</u>
15	<u>0</u>
16	<u>0</u>

DAY AVG. DAILY POWER LEVEL
(MWe-Net)

17	<u>0</u>
18	<u>0</u>
19	<u>0</u>
20	<u>0</u>
21	<u>0</u>
22	<u>0</u>
23	<u>0</u>
24	<u>0</u>
25	<u>0</u>
26	<u>0</u>
27	<u>0</u>
28	<u>0</u>
29	<u>0</u>
30	<u>0</u>
31	<u>0</u>

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

REFUELING INFORMATION REQUEST

1. Name of the facility: Millstone Unit 1
2. Scheduled date for next refueling outage: Current refueling outage started November 1995. Next refueling outage date to be determined.
3. Scheduled date for restart following refueling: To be determined
4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?
Yes, however the entire scope is to be determined.
5. Scheduled date(s), if submitting licensing action and supporting information:
None at this time
6. Important licensing considerations associated with refueling, e.g., new or different fuel design or supplier, unreviewed design or performance analysis methods, significant changes in fuel design, new operating procedures:
184 GE-11 fuel assemblies
7. The number of fuel assemblies (a) in the core and (b) in the spent fuel storage pool:
In Core: (a) 0 In Spent Fuel Pool: (b) 3068 Unconsolidated
8. The present licensed spent fuel pool storage capacity and the size of any increase in licensed storage capacity that has been requested or is planned, in number of fuel assemblies:
Present Capacity: Maximum 3229 fuel assembly locations
9. The projected date of the last refueling that can be discharged to the spent fuel pool assuming present license capacity:
1998/1999, spent fuel pool full, core offload capacity is reached