



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

COMM.
TRANSITION

December 17, 1980

IS NRC
DISTRIBUTION SERVICES
BRANCH

1980 DEC 19 AM 10 45

DISTRIBUTION
SERVICES UNIT

MEMORANDUM FOR: Chairman Ahearne
Commissioner Gilinsky
Commissioner Hendrie
Commissioner Bradford

FROM: William J. Dircks, Executive Director for Operations

SUBJECT: DAILY STAFF NOTES, DECEMBER 16, 1980

IE

1. Lebanon Valley General Hospital, Lebanon, Pa. - Loss of 10 Millicuries of Xenon-133, (PNO-I-80-174).
2. Brunswick Steam Electric Plant (Carolina Power & Light) - Loss of Reactor Building Airborne Effluent Monitoring Capability, (PNO-II-80-174).
3. Mallinckrodt, Inc., St. Louis, Mo. - Report on Lost Shipment of Radioactive Material: 3 Curie Technetium Generator, (PNO-III-80-231).
4. Arkansas Nuclear One, Unit 2 - Plant Shutdown Extended, (PNO-IV-80-40A).
5. Quad-Citties, Unit 1 and 2 - Bomb Threat, (PNS-III-80-22).

NRR

Joseph M. Farley, Unit No. 1

On December 12, 1980 we were informed by Alabama Power Company and Westinghouse that inspection of both LP turbines at Farley-1 had been completed. Multiple bore and keyway cracks, as well as indications on the disc face were observed in the first and second discs. The licensee is tentatively planning to replace both rotors before restarting the plant in March 1981.

8101070 487

THIS DOCUMENT CONTAINS
POOR QUALITY PAGES

REGION III PLANT STATUS- 12/16/80

PLANT NAME	PLANT STATUS		REASON OR COMMENT	RESTART DATE
	% POWER	DOWN		
BIG ROCK POINT		X	REFUELING	1/7
COOK 1	100			
COOK 2	35		GENERATOR EXCITER REPLACED.	
			INCREASING POWER	
DAVIS-BESSE 1	54		RC PUMP SEAL AND FW PUMP DOWN	
DRESDEN 1		X	CHEMICAL CLEANING	INDEF
DRESDEN 2	47		COAST DOWN	
DRESDEN 3	99			
DWANE ARNOLD	99			
KEWAUNEE	100			
LACROSSE		X	REFUELING	1/31
LACALLE		X	AWAITING LICENSE	
MONTICELLO	100			
PALESADES	43		LIMITED BY CONDENSER VACUUM	
POINT BEACH 1		X	REFUELING	12/25
POINT BEACH 2	100			
PRAIRIE ISLAND 1	90		AXIAL OFFSET TEST IN PROGRESS	
PRAIRIE ISLAND 2	100			
QUAD CITIES 1		X	REFUELING	12/21
QUAD CITIES 2	90		INCREASING POWER SINCE	
			REACTOR TRIP	
ION 1	83		LIMITED BY RAD WASTE	
ION 2	93		LP HEATER STRING LIMITED	

REGION IV PLANT STATUS- 12/16/80

PLANT NAME	PLANT STATUS		REASON OR COMMENT	RESTART DATE
	% POWER	DOWN		
ARKANSAS 1	72		3 PUMPS LIMIT; LEAKING PUMP	
ARKANSAS 2		X	HEATING UP NOW TO HOT STANDBY	
COOPER	95			
FORT CALHOUN	75		ADMINISTRATIVE CONTROL (FUEL	
			CONSERVATION)	
FORT ST. VRAIN	5		SHUTTING DOWN	

REGION V PLANT STATUS- 12/16/80

PLANT NAME	PLANT STATUS		REASON OR COMMENT	RESTART DATE
	% POWER	DOWN		
DIABLO CANYON		X	AWAITING LICENSE	
ANCHOR SECO	100			
AN ONOFRE		X	STEAM GENERATOR TUBE REPAIR	4/16
DOUAN	100			

- REASON OR COMMENT HAS CHANGED IN PAST 24 HOURS

- REACTOR SCRAM WITHIN PAST 24 HOURS

NOTE - REACTOR STATUS DATA COLLECTED BETWEEN
6 A. M. AND 8 A. M. EACH DAY EXCEPT
HOLIDAYS AND WEEKENDS

REGION I PLANT STATUS- 12/16/80

PLANT NAME	PLANT STATUS		REASON OR COMMENT	RESTART DATE
	% POWER	DOWN		
BEAVER VALLEY 1	100			
CALVERT CLIFFS 1		X	REFUELING	12/15
CALVERT CLIFFS 2	66		COASTING DOWN	
FITZPATRICK	100			
GINNA	100			
HOODAM NECK	100			
INDIAN POINT 2		X	REFUELING AND REPAIR FAN COOLERS	6/81
INDIAN POINT 3		X	MAINTENANCE ON RCP	
MAINE YANKEE		X	CHECKING FOR POSSIBLE SEAL PROBLEMS	
MILLSTONE 1		X	DEFUELED	1/15
MILLSTONE 2	100			
NINE MILE POINT 1	80		PRECONDITIONING	
NOTER CREEK	96			
ORCH BOTTOM 2	100			
ORCH BOTTOM 3	100			
PILGRIM 1	100			
SALEM 1		X	REFUELING	
SALEM 2		X	AWAITING LICENSE	
THREE MILE ISLAND 1		X	NRC ORDER	
THREE MILE ISLAND 2		X	NRC ORDER	
VERMONT YANKEE		X	REFUELING	12/22
YANKEE ROWE	100			

REGION II PLANT STATUS- 12/16/80

PLANT NAME	PLANT STATUS		REASON OR COMMENT	RESTART DATE
	% POWER	DOWN		
BROWNS FERRY 1	98			
BROWNS FERRY 2	99			
BROWNS FERRY 3		X	REFUELING	1/9
BRUNSWICK 1	92		ROD PATTERN CHANGE - NEW FILTERS ON CONDENSATE TRAIN	
BRUNSWICK 2	77		INCREASING POWER	
CRYSTAL RIVER 3	100			
FARLEY 1		X	RELOADING - HEAD STILL OFF; INTERNALS IN PLACE	3/1
HATCH 1	80		CONSERVING FUEL	
HATCH 2		X	REFUELING	3/1
NORTH ANNA 1	65		COAST DOWN	
NORTH ANNA 2	100			
OCONEE 1	100			
OCONEE 2	100			
OCONEE 3		X	REFUELING	
ROBINSON 2	67		INCREASING 2% PER HOUR DUE TO WASTE WATER LIMIT	
SEQUOYAH 1	38		POWER ASCENSION TO 75% AT 0500	
ST. LUCIE 1	100			
SURRY 1		X	S. G. REPLACEMENT	8/81
SURRY 2	100			
TURKEY POINT 3	100			
TURKEY POINT 4		X	REFUELING	1/15